

County comments for C20-25 1000330592 Ontario Inc.



Hello Southgate,

Please see below for the County comments for Zoning application C20-25 1000330592 Ontario Inc. - 1000330592 Ontario Inc..

County Planning Ecology staff have reviewed the subject application and provided the following comments:

The response matrix was reviewed and Ecology comments have been acknowledged. The site plan has changed slightly regarding the location of the septic tanks. The proposed location of the southern septic tank has shifted toward the rear portion of the development envelope, but remains situated within the development envelope. County Planning Ecology staff have no further comments at this time.

County Transportation Services have reviewed the subject application and provided the following comments:

The revised site plan shows the septic tanks being 23 metres from the centreline of the County Road. Provided the septic tanks are located at least 23 metres from the centreline of the County Road, County Transportation have no concerns

County Planning staff have no additional comments regarding the County comments dated November 19, 2025.

Please note, a paper copy will not be provided unless requested.

Let us know if you have any questions.

Best regards,

[Redacted signature]