



## **Township of Southgate**

# **Dundalk Waterworks**

## **2025 Annual Report**

**9.1.2PW2026-007 - Dundalk Drinking Water 2025 Annual Report**  
No. 2026-060

**Moved By** Deputy Mayor Dobreen  
**Seconded By** Councillor John

**Be it resolved that** Staff Report PW2026-007 be received for information; and  
**That** Council approve the Dundalk Drinking Water 2025 Annual Report.

**Carried**

**Cory Henry**  
Public Works Manager – Water Operations

# Dundalk Waterworks 2025 Annual Report

## Table of Contents

Township of Southgate Annual Water Report.....	1
Summary of all Test Results.....	2
Average Day Well Consumption vs. Maximum Flow/Day Allowed.....	5
Maximum One Day Well Consumption vs. Maximum Flow Allow.....	6
Total Well Consumption vs. Maximum Flow Allowed.....	7
Ministry of the Environment Annual Report.....	8
Annual Sampling Results.....	16
Distribution System Bacteriological Data – Annual Summary.....	17
Input into the Distribution System Bacteriological Data – Treated Water Well 3.....	18
Input into the Distribution System Bacteriological Data – Treated Water Well 4.....	19
Input into the Distribution System Bacteriological Data – Treated Water Well 5.....	20
Raw Water Bacteriological Data –Well 3.....	21
Raw Water Bacteriological Data –Well 4.....	22
Raw Water Bacteriological Data -Well 5.....	23
Input into the Distribution System Bacteriological Data – Chlorine Residuals Well 3.....	24
Input into the Distribution System Bacteriological Data – Chlorine Residuals Well 4.....	25
Input into the Distribution System Bacteriological Data – Chlorine Residuals Well 5.....	26
Fluoride, Nitrite, Nitrate and Colour – Well 3.....	27
Fluoride, Nitrite, Nitrate and Colour – Well 4.....	28
Fluoride, Nitrite, Nitrate and Colour – Well 5.....	29
Treated Water Volatile Organic & Inorganic Data – Well 3.....	30
Treated Water Volatile Organic & Inorganic Data – Well 4.....	31
Treated Water Volatile Organic & Inorganic Data – Well 5.....	32
Parameters Not Listed in the Minimum Sampling Program – Well 3.....	33
Parameters Not Listed in the Minimum Sampling Program – Well 4.....	34
Parameters Not Listed in the Minimum Sampling Program – Well 5.....	35
Distributed Water Volatile Organic & Inorganic Data.....	36

# **Dundalk Waterworks - Township of Southgate**

## **2025 Annual Water Report**

**Site:**

Village of Dundalk

**Operations Address:**

75 Dundalk Street,  
Dundalk, Ontario N0C 1B0

**Waterworks #:**

220001753

**Municipal Drinking Water Licence:** 110-101, Issue No. 5

**Drinking Water Works Permit:** 110-201, Issue No. 6

**Period of this Report:** January 1- December 31 **Year:** 2025

### **Description of System**

The water system known as Dundalk Water Works is a ground water source consisting of three production wells, one monitoring well and a distribution system. The system is monitored by a SCADA system installed in 2006 which communicates through RF towers and PLC's in the wells to record data and monitor operations.

Well D3 is equipped with a submersible pump, flow meter, two ultra violet sterilization chambers and a chemical feed pump for sodium hypochlorite and is connected to a 1365 m<sup>3</sup> baffled storage tank with 2 pax mixers. Two turbine high lift pumps pump from storage through a flow meter into a distribution system and a booster chemical feed pump are connected after the reservoir and starts automatically if the chlorine residual begins to fall. This well has a capacity of 1181 m<sup>3</sup>/day. This pump house is equipped with two chlorine analyzers, one prior to the reservoir and the second installed prior to entering the distribution system. The entire system is under the control of a PLC system and any failures alarm a dial out system to alert operators. Well D3 is equipped with an 80 kW diesel generator that starts automatically in the event of a power outage and is capable of providing power to maintain this water supply.

Well D4 was constructed in 2004 and is equipped with a submersible pump, flow meter and a chemical feed pump for sodium hypochlorite and is connected to a 187.7 m<sup>3</sup> baffled reservoir. Two turbine high lift pumps pump from storage through a flow meter into a distribution system and a booster chemical feed pump is connected after the reservoir that automatically starts if the chlorine residual begins to fall. This well has a 1637 m<sup>3</sup>/day capacity. This pump house is equipped with two chlorine analyzers, one prior to the reservoir and the second installed prior to entering the distribution system. The entire system is under the control of a PLC system and any failures alarm a dial out system to alert operators. Well D4 is equipped with a 100 kW diesel generator with automatic transfer switch for standby power.

Well D5 was drilled in 2017 with the well house and reservoir built in 2019. It is equipped with a 15hp submersible pump that fills a rectangular baffled reservoir with a capacity of 536 cubic meters. Two turbine high lift pumps pump from storage through a flow meter into a distribution system and a booster chemical feed pump is connected after the reservoir that automatically starts if the chlorine residual begins to fall. This well has a 1961 m3/day capacity. This pump house is equipped with two chlorine analysers, one prior to the reservoir and the second installed prior to entering the distribution system. The entire system is under the control of a PLC system and any failures alarm a dial out system to alert operators. Well D5 is equipped with a 150 kW diesel generator with automatic transfer switch for standby power.

In September of 2023, the water tower was added to the system. It is located next to Well 4, which supplies the back up power for the tower. The tower can hold 4000 cubic meters of water. There is a recirculation pump that can be used to cycle the water and also boost chlorine levels if needed.

The distribution system is made up of a network of water mains of varying size with 1,633 service connections.

## **Summary of all Test Results**

### **Treated Water Recap:**

No. of Distribution Samples taken	260
No. of Treated Water Well Samples taken	155
No. of samples with Total Coliform	0
No. of samples with E Coli	0
No. of treated samples with Heterotrophic Plate Count >500	0

### **Raw Water Recap:**

No. of Raw Water Well Samples taken	143
No. of Raw samples with Total Coliform	1
No. of Raw samples with E Coli	0
No. of Raw samples with Heterotrophic Plate Count > 500	0

Heterotrophic Plate Counts are conducted on some treated and distribution system samples. The HPC test is used as a tool to monitor overall quality, but the results are not indicators of water safety. There is not a Drinking Water Quality Standard for HPC.

## **Summary of Adverse Test Results Reported: -**

There were 2 incidents of Adverse Drinking Water:

- January 9, 2025 – Fluoride

On January 9, 2025, the Township received adverse fluoride from Well D5. The fluoride level for Well D5 was 1.9 mg/L with the MAC (Maximum Allowable Concentration) being 1.5 mg/L.

**Description of action taken:**

- Reported to the MECP SAC and the Public Health Unit – AWQI#167187 on January 9, 2025. A resample was taken on January 10, 2025 with a fluoride result of 1.8 mg/L. Post the fluoride fact sheet on the Township of Southgate website and Facebook page, as well as the back of the next water bill. Also email the schools and daycares a copy of the fact sheet. This is reportable every 57 months.
- August 4, 2025 – Well 4 High turbidity  
On August 4, 2025 operators found turbidity to be 2.95 NTU at Well 4. Well 4 was shut down immediately. Fire hydrants in the area were flushed finding turbidity at or below 1.0 NTU.

**Description of action taken:**

- Fire hydrants in the area were flushed, finding turbidity at or below 1.0 NTU
- Reported to the MECP SAC and Public Health Unit – AWQI#169334 on August 8, 2025.
- Shut down Well 4 until issue is resolved.
- Small camera used to video the well casing. No major observations were found.
- Flushing to waste and testing/sampling. After approximately 3 weeks, numbers improved and lab results were good. Well 4 was put back into operation on August 22, 2025.
- Further troubleshoot to commence when well technicians could schedule.

**Description of Major Equipment Expenses:**

- Victoria Street construction = \$177,750
- Debt Well D5/ Main St E = \$342,473.00
- Main St W Predesign = \$3,000.00
- Osprey St Predesign = \$13,000.00
- PLC's for Wells (3) – Hardware/Software = \$13,205.18 (down payment)

**New Equipment Installed:**

08/25/2025 New fire hydrant installed at 251 Young St.

**Equipment Replaced:**

01/23/2025 - Replaced Well 3, reservoir level transducer.

01/23/2025 – Replaced Well 3, treated water flow meter.

02/26/2025 – Replaced Well 3, electrical units for well pump.

03/21/2025 – Replaced Well 3 cooling fan in VFD for HLP #1.

12/02/2025 - Scada hard drives replaced.

**Repairs to Equipment:**

Nothing to report.

**Frozen Water:**

Nothing to report.

**Township of Southgate - Dundalk Waterworks**  
**Average Day Well Consumption vs. Maximum Flow/Day Allowed Report 2025**

Month	Average Day Water Consumption Well #3	Maximum Flow Rate Allowed Well #3/Day	Average Day Water Consumption Well #4	Maximum Flow Rate Allowed Well #4/Day	Average Day Water Consumption Well #5	Maximum Flow Rate Allowed Well #5/Day	Average Day Water Consumption All Wells	Maximum Flow Rate Allowed All Wells/Day
January	320	1,182	357	1,637	277	1,961	954	2,817
February	376	1,182	357	1,637	272	1,961	1,005	2,817
March	386	1,182	366	1,637	257	1,961	1,009	2,817
April	397	1,182	356	1,637	259	1,961	1,012	2,817
May	392	1,182	358	1,637	253	1,961	1,003	2,817
June	383	1,182	356	1,637	303	1,961	1,042	2,817
July	385	1,182	361	1,637	269	1,961	1,015	2,817
August	396	1,182	117	1,637	533	1,961	1,046	2,817
September	405	1,182	169	1,637	427	1,961	1,000	2,817
October	423	1,182	0	1,637	538	1,961	960	2,817
November	455	1,182	0	1,637	574	1,961	1,029	2,817
December	424	1,182	0	1,637	685	1,961	1,109	2,817
<b>Annual Monthly Average in M<sub>3</sub></b>	<b>395</b>	<b>1,182</b>	<b>233</b>	<b>1,637</b>	<b>387</b>	<b>1,961</b>	<b>1,015</b>	<b>2,817</b>

**Note: Flow in above chart is in Cubic Meters**

<b>Certificate of Approval Well Pumping Maximum Flow Rate per Day</b>				
Well	Maximum Pump Rate in Liters/Min.	Maximum Pump Rate in Liters/Day	Maximum Pump Rate in m <sup>3</sup> /Day	Maximum Pump Rate in Gallons/Day
Well #3	820	1,180,800	1181	259,985
Well #4	1137	1,637,280	1636	360,149
Well #5	1362	1,961,280	1961	431,695
<b>Total</b>		<b>2817</b>		<b>620,134</b>

**Township of Southgate - Dundalk Waterworks**  
**Maximum One Day Well Consumption vs. Maximum Flow Allowed Report 2025**

Month	Maximum One Day Consumption Well #3	Maximum Flow Allowed/Day Well #3	Maximum One Day Consumption Well #4	Maximum Flow Allowed/Day Well #4	Maximum One Day Consumption Well #5	Maximum Flow Allowed/Day Well #5	Maximum One Day Flow All Wells	Maximum Flow Allowed/Day All Wells
January	618	1,182	440	1,637	815	1,961	1,228	4,780
February	513	1,182	636	1,637	655	1,961	1,687	4,780
March	734	1,182	656	1,637	589	1,961	1,979	4,780
April	663	1,182	442	1,637	488	1,961	1,282	4,780
May	564	1,182	426	1,637	365	1,961	1,188	4,780
June	421	1,182	428	1,637	435	1,961	1,270	4,780
July	439	1,182	464	1,637	398	1,961	1,184	4,780
August	858	1,182	360	1,637	900	1,961	1,662	4,780
September	508	1,182	489	1,637	968	1,961	1,585	4,780
October	705	1,182	0	1,637	1,413	1,961	2,118	4,780
November	787	1,182	0	1,637	883	1,961	1,293	4,780
December	498	1,182	0	1,637	989	1,961	1,442	4,780
<b>Annual Maximum for One Day - m<sup>3</sup></b>	858	1182	656	1637	1413	1961	2118	4780
<b>Annual Maximum for One Day - Gal</b>	188,880	260,205	144,412	360,369	311,058	431,695	466,257	1,052,269

Note: Flow in above chart is in Cubic Meters

**Certificate of Approval Well Pumping Maximum Capacity per Day**

Well	Maximum Pump Rate in Liters/Min.	Maximum Pump Rate in Liters/Day	Maximum Pump Rate in m/Day	Maximum Pump Rate in Gallons/Day
Well #3	822	1,183,680	1181	259,985
Well #4	1134	1,632,960	1636	360,149
Well #5	1362	1,961,280	1961	431,695
<b>Total</b>		2817	620,134	

**Township of Southgate - Dundalk Waterworks**  
**Total Well Consumption vs. Maximum Flow Allowed Report 2025**

Month	Water Consumption Well #3	Monthly Flow Allowed Well #3	Water Consumption Well #4	Monthly Flow Allowed Well #4	Water Consumption Well #5	Monthly Flow Allowed Well #5	# of Days in Month
January	9,927	36,611	11,067	50,716	8,600	60,791	31
February	10,516	33,068	10,007	45,808	7,604	54,908	28
March	11,979	36,611	11,338	50,716	7,956	60,791	31
April	11,909	35,430	10,690	49,080	7,776	58,830	30
May	12,147	36,611	11,084	50,716	7,836	60,791	31
June	11,493	35,430	10,670	49,080	9,104	58,830	30
July	11,943	36,611	11,192	50,716	8,329	60,791	31
August	12,273	36,611	3,637	50,716	16,515	60,791	31
September	12,137	35,430	5,059	49,080	12,810	58,830	30
October	13,103	36,611	0	50,716	16,666	60,791	31
November	13,656	35,430	0	49,080	17,228	58,830	30
December	13,131	36,611	0	50,716	21,241	60,791	31
<b>Annual Flow in m3</b>	<b>144,214</b>	<b>431,065</b>	<b>84,744</b>	<b>597,140</b>	<b>141,665</b>	<b>715,765</b>	

**Certificate of Approval Well Pumping Maximum Flow Rate per Day**

Well	Maximum Pump Rate in Liters/Min.	Maximum Pump Rate in Liters/Day	Maximum Pump Rate in m <sup>3</sup> /Day	Maximum Pump Rate in Gallons/Day	Water Consumption in m <sup>3</sup> by Well in 2023	Annual Flow Allowed at each Wells
Well #3	822	1,183,680	1181	259,985	144,214	431,065
Well #4	1134	1,632,960	1636	360,149	84,744	597,140
Well #5	1362	1,961,280	1961	431,695	141,665	715,765
<b>Total</b>			<b>2817</b>	<b>620,134</b>	<b>370,623</b>	<b>1,743,970</b>



## OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:

220001753

Drinking-Water System Name:

Dundalk Waterworks

Drinking-Water System Owner:

Township of Southgate

Drinking-Water System Category:

Large Municipal – Residential

Period being reported:

January 1 to December 31, 2025

**Complete if your Category is Large Municipal Residential or Small Municipal Residential**

Does your Drinking-Water System serve more than 10,000 people? Yes  No

Is your annual report available to the public at no charge on a web site on the Internet?  
Yes  No

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

- Southgate Municipal Office (near Hopeville) 185667 Grey Road 9, RR 1 Dundalk ON N0C 1B0
- Dundalk Works Depot 75 Dundalk St Dundalk ON N0C 1B0
- Dundalk Library 80 Proton Street North

**Complete for all other Categories.**

Number of Designated Facilities served:

3

Did you provide a copy of your annual report to all Designated Facilities you serve?

Yes  No

Number of Interested Authorities you report to:

3

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?

Yes  No

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes  No



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method \_\_\_\_\_

### Describe your Drinking-Water System

Dundalk Waterworks has three operational wells. The Township has a 1306 m<sup>3</sup> of storage in an above ground baffled reservoir at Well 3, a 187.7 m<sup>3</sup> baffled reservoir at Well D4 and a 536 m<sup>3</sup> baffled reservoir at Well D5. The water is pumped by high lift pumps into the distribution and fills the Dundalk Water Tower adjacent to Well D4. Well pumping and tower refilling are programmed for off peak hydro rates savings. All wells, and the water tower communicate by fiber-& wireless-connections to control which well is in the lead and all other operating parameters and alarms are monitored by SCADA through the same communications system.

### List all water treatment chemicals used over this reporting period

Sodium Hypochlorite

### Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

### Please provide a brief description and a breakdown of monetary expenses incurred

- 251 Young St, fire hydrant installation - \$9,000.00
- Well 3 Treated flow meter replacement - \$9,500.00
- Scada hard drive replacement - \$10,300.00

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
01/09/2025	Fluoride	1.9	Mg/L	Re-sample	01/10/2025
01/10/2025	Fluoride	1.8	Mg/L	Public notification	Jan/Mar/25

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	143	0-0	0-1	143	<10 - 420
Treated	155	0-0	0-0	155	<10 - 160
Distribution	260	0-0	0-0	260	<10 - 1260

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	33	0.02 - 0.17
Chlorine	573 8760 - D3 8760 - D4 8760 - D5	Distribution Free 0.42 - 1.32 Treated Free 0.38 - 1.64 Treated Free 0.49 - 1.32 Treated Free 0.85 - 1.35
Fluoride (If the DWS provides fluoridation)		

**NOTE:** For continuous monitors use 8760 as the number of samples.

**NOTE:** Record the unit of measure if it is **not** milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
Drinking Water License 110-101 Issue Number 5 (01/28/2021), Permit 110-201 Issue Number 6 (11/29/2023),	Sodium	March 4, 2025 July 15, 2025	D3-28.0 D4-22.9 D5-13.7 D3 - 24.9 D4 - 21.8 D5 - 12.4	Mg/L



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

	Sodium	March 4, 2024	D3 – 30.2 D4 – 30.3 D5 – 13.3	Mg/L
“	D3 Gross Alpha	March 25, 2025	D3 - 0.15 D4 - < 0.10 D5 - < 0.10	Bq/L
“	D3 Gross Beta	“	D3 - 0.16 D4 - < 0.10 D5 - < 0.10	Bq/L
“	D3 Tritium	“	D3 - < 15 D4 - < 15 D5 - < 15	Bq/L

## Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	March/4/24	D3-<0.0001 D4-<0.0001 D5-<0.0001	mg/l	
Arsenic	March/4/24	D3-0.0012 D4-0.0004 D5-0.0007	“	
Barium	March/4/24	D3-0.107 D4-0.099 D5-0.104	“	
Boron	March/4/24	D3-0.047 D4-0.039 D5-0.043	“	
Cadmium	March/4/24	D3-<0.000015 D4-<0.000015 D5-<0.000015	“	
Chromium	March/4/24	D3-<0.0010 D4-<0.0010 D5-<0.0010	“	
*Lead	March 12/24 September 10/24	Low-0.00016 High-0.00030 Low-0.00035 High-0.00048	mg/l	
Mercury	March/4/24	D3-<0.00002 D4-<0.00002 D5-<0.00002	“	
Selenium	March/4/24	D3-<0.001 D4-<0.001 D5-<0.001	“	
Sodium	July/15/25	D3-24.9 D4-21.8 D5-12.4	mg/l	
Uranium	March/4/24	D3-0.00210 D4-0.00174 D5-0.00035	mg/l	
Fluoride	July/15/25	D3-0.5 D4-1.0	mg/l	



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

		<b>D5-1.8</b>		
Nitrite	<b>October 7, 2025</b>	D3-<0.05 D4-<0.05 D5-<0.05	mg/l	
Nitrate	<b>October 7, 2025</b>	D3-<0.05 D4-2.06 D5-<0.05	mg/l	

\*Only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

## Summary of lead testing under Schedule 15.1 during this reporting period

(Applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

\*Note: Municipality is on reduced sampling schedule currently.

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Residential	Exempt from sampling		
Non-Residential	Exempt from sampling		
Distribution	Alkalinity only	0.00016mg/L to 0.00048 mg/L	0

## Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	March 4/24	D3-<0.3 D4-<0.3 D5-<0.3	ug/l	
Aldicarb	March 9/15	0.01	“	
Aldrin + Dieldrin	March 9/15	0.01	“	
Atrazine + N-dealkylated metabolites	March 4/24	D3-<0.5 D4-<0.5 D5-<0.5	“	
Azinphos-methyl	March 4/24	D3-<1 D4-<1 D5-<1	ug/l	
Bendiocarb	March 9/15	0.01	“	
Benzene	March 4/24	D3-<0.5 D4-<0.5 D5-<0.5	“	
Benzo(a)pyrene	March 4/24	D3-<0.006 D4-<0.006 D5-<0.006	“	



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

<b>Bromoxynil</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>Carbaryl</b>	March 4/24	<b>D3-&lt;3 D4-&lt;3 D5-&lt;3</b>	“	
<b>Carbofuran</b>	March 4/24	<b>D3-&lt;1 D4-&lt;1 D5-&lt;1</b>	“	
<b>Carbon Tetrachloride</b>	March 4/24	<b>D3-&lt;0.2 D4-&lt;0.2 D5-&lt;0.2</b>	“	
<b>Chlordane (Total)</b>	March 9/15	<b>0.01</b>	“	
<b>Chlorpyrifos</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>Cyanazine</b>	March 9/15	<b>0.03</b>	“	
<b>Diazinon</b>	March 4/24	<b>D3-&lt;1 D4-&lt;1 D5-&lt;1</b>	“	
<b>Dicamba</b>	March 4/24	<b>D3-&lt;1 D4-&lt;1 D5-&lt;1</b>	“	
<b>1,2-Dichlorobenzene</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>1,4-Dichlorobenzene</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>Dichlorodiphenyltrichloroethane (DDT) + metabolites</b>	March 9/15	<b>0.01</b>	“	
<b>1,2-Dichloroethane</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>1,1-Dichloroethylene (vinylidene chloride)</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>Dichloromethane</b>	March 4/24	<b>D3-&lt;5 D4-&lt;5 D5-&lt;5</b>	“	
<b>2-4 Dichlorophenol</b>	March 4/24	<b>D3-&lt;0.2 D4-&lt;0.2 D5-&lt;0.2</b>	“	
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>	March 4/24	<b>D3-&lt;1 D4-&lt;1 D5-&lt;1</b>	“	
<b>Diclofop-methyl</b>	March 4/24	<b>D3-&lt;0.9 D4-&lt;0.9 D5-&lt;0.9</b>	“	
<b>Dimethoate</b>	March 4/24	<b>D3-&lt;1 D4-&lt;1 D5-&lt;1</b>	“	
<b>Dinoseb</b>	March 9/15	<b>0.36</b>	“	



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

Diquat	March 4/24	D3-<5 D4-<5 D5-<5	“	
Diuron	March 4/24	D3-<5 D4-<5 D5-<5	“	
Glyphosate	March 4/24	D3-<25 D4-<25 D5-<25	“	
Heptachlor + Heptachlor Epoxide	March 9/15	<b>0.01</b>	“	
Haloacetic Acids (Bromoacetic Acid, Chloroacetic Acid, Dichloroacetic Acid, Dibromoacetic Acid, and Trichloroacetic Acid)	October 7/25	<b>6.975</b>	”	
Lindane (Total)	March 9/15	<b>0.01</b>	“	
Malathion	March 4/24	D3-<5 D4-<5 D5-<5	“	
Methoxychlor	March 5/18	<b>0.03</b>	“	
2-methyl-4-chlorophenoxyacetuc acid	March 5/18	<b>0.00012</b>	mg/l	
Metolachlor	March 4/24	D3-<3 D4-<3 D5-<3	ug/l	
Metribuzin	March 4/24	D3-<3 D4-<3 D5-<3	“	
Monochlorobenzene	March 1/21	<b>&lt;0.5</b>	“	
Paraquat	March 4/24	D3-<1 D4-<1 D5-<1	“	
Parathion	March 9/15	<b>0.02</b>	“	
Pentachlorophenol	March 4/24	D3-<0.2 D4-<0.2 D5-<0.2	“	
Phorate	March 4/24	D3-<0.3 D4-<0.3 D5-<0.3	“	
Picloram	March 4/24	D3-<5 D4-<5 D5-<5	“	
Polychlorinated Biphenyls(PCB)	March 4/24	D3-<0.5 D4-<0.5 D5-<0.5	“	
Prometryne	March 4/24	D3-<0.1 D4-<0.1 D5-<0.1	“	
Simazine	March 5/18	<b>0.01</b>	“	
THM (NOTE: show latest running annual average)	October 7/25	<b>16.125</b>	ug/l	
Temephos	March 9/15	<b>0.01</b>	“	



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

<b>Terbufos</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>Tetrachloroethylene</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>2,3,4,6-Tetrachlorophenol</b>	March 4/24	<b>D3-&lt;0.2 D4-&lt;0.2 D5-&lt;0.2</b>	“	
<b>Triallate</b>	March 4/24	<b>D3-&lt;10 D4-&lt;10 D5-&lt;10</b>	“	
<b>Trichloroethylene</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>2,4,6-Trichlorophenol</b>	March 4/24	<b>D3-&lt;0.2 D4-&lt;0.2 D5-&lt;0.2</b>	“	
<b>2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)</b>	March 9/15	<b>0.22</b>	“	
<b>Trifluralin</b>	March 4/24	<b>D3-&lt;0.5 D4-&lt;0.5 D5-&lt;0.5</b>	“	
<b>Vinyl Chloride</b>	March 4/24	<b>D3-&lt;0.2 D4-&lt;0.2 D5-&lt;0.2</b>	“	

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample

**Annual Sampling Results 2025**

Year: 2025

Parameter	Ecoli						Total Coliform						HPC						Background		Raw Water Turbidity		Treated Chlorine Free		Treated Turbidity		Distribution Chlorine Free		Distribution Turbidity	
	Raw		Treated		Distribution		Raw		Treated		Distribution		RW-Raw		TW-Treated		DW-Distribution				Raw Water Turbidity		Treated Chlorine Free		Treated Turbidity		Distribution Chlorine Free		Distribution Turbidity	
	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High		
January	0	0	0	0	0	0	0	0	0	0	0	0	<10	10	<10	10	<10	360			0.07	0.09	0.66	1.21	0.06	0.37	0.58	1.20	0.09	0.43
February	0	0	0	0	0	0	0	0	0	0	0	0	<10	10	<10	<10	<10	180			0.07	0.08	0.84	1.64	0.05	0.39	0.84	1.18	0.10	0.36
March	0	0	0	0	0	0	0	0	0	0	0	0	<10	10	<10	10	<10	20			0.06	0.08	0.80	1.44	0.05	0.39	0.70	1.19	0.09	0.30
April	0	0	0	0	0	0	0	0	0	0	0	0	<10	<10	<10	40	<10	160			0.06	0.08	0.79	1.39	0.03	0.80	0.52	0.32	0.10	0.33
May	0	0	0	0	0	0	0	0	0	0	0	0	<10	10	<10	20	<10	70			0.09	0.14	0.69	1.45	0.03	0.38	0.64	1.27	0.07	0.35
June	0	0	0	0	0	0	0	0	0	0	0	0	<10	10	<10	90	<10	1260			0.06	0.08	0.88	1.37	0.01	0.38	0.61	1.22	0.09	0.33
July	0	0	0	0	0	0	1	0	0	0	0	0	<10	130	<10	30	<10	390			0.02	0.05	0.84	1.22	0.01	0.46	0.71	1.19	0.04	0.73
August	0	0	0	0	0	0	0	0	0	0	0	0	<10	120	<10	110	<10	100			0.06	0.33	0.53	1.26	0.01	2.95	0.47	1.16	0.03	0.71
September	0	0	0	0	0	0	0	0	0	0	0	0	<10	80	<10	<10	<10	130			0.14	0.17	0.89	1.31	0.01	0.43	0.41	1.33	0.07	0.38
October	0	0	0	0	0	0	0	0	0	0	0	0	<10	420	<10	20	<10	420			0.07	0.08	0.49	1.31	0.01	0.44	0.57	1.14	0.06	0.38
November	0	0	0	0	0	0	0	0	0	0	0	0	<10	<10	<10	10	<10	60			0.10	0.11	0.52	1.52	0.01	0.43	0.54	1.29	0.01	0.74
December	0	0	0	0	0	0	0	0	0	0	0	0	<10	10	<10	160	<10	150			0.01	0.01	0.61	1.35	0.01	0.50	0.67	1.22	0.02	0.45
Recap for Year	0	0	0	0	0	0	1	0	0	0	0	0	420	0	160	0	1260	-	-	0.01	0.33	0.49	1.64	0.01	2.95	0.41	1.33	0.01	0.74	

Lab Reports

## Annual Summary - Distribution System Bacteriological Data

**Water Works Name:** Dundalk Water Works  
**Year:** 2025  
**Serviced Population:** 2864  
**Laboratories Which Performed Analyses:** Caduceon Labs

### **Distribution System**

Month	Total Coliform			Fecal Coliform/Escherichia Coli			HPC or MF		
	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"
January	20	20	0	20	20	0	20	20	0
February	20	20	0	20	20	0	20	20	0
March	20	20	0	20	20	0	20	20	0
April	25	25	0	25	25	0	25	25	0
May	20	20	0	20	20	0	20	20	0
June	25	25	0	25	25	0	25	25	0
July	20	20	0	20	20	0	20	20	0
August	20	20	0	20	20	0	20	20	0
September	25	25	0	25	25	0	25	25	0
October	20	20	0	20	20	0	20	20	0
November	20	20	0	20	20	0	20	20	0
December	25	25	0	25	25	0	25	25	0
<b>Total</b>	<b>260</b>	<b>260</b>	<b>0</b>	<b>260</b>	<b>260</b>	<b>0</b>	<b>260</b>	<b>260</b>	<b>0</b>

## Input into the Distribution System Bacteriological Data

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well #3  
**Year:** 2025  
**Serviced Population:** 2864  
**Laboratories Which Performed Analyses:** Caduceon Labs

### Treated Water

Month	Total Coliform			Fecal Coliform/Escherichia Coli			HPC or MF		
	No. of Samples	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"
January	4	4	0	4	4	0	4	4	0
February	4	4	0	4	4	0	4	4	0
March	4	4	0	4	4	0	4	4	0
April	5	5	0	5	5	0	5	5	0
May	4	4	0	4	4	0	4	4	0
June	5	5	0	5	5	0	5	5	0
July	4	4	0	4	4	0	4	4	0
August	4	4	0	4	4	0	4	4	0
September	5	5	0	5	5	0	5	5	0
October	4	4	0	4	4	0	4	4	0
November	4	4	0	4	4	0	4	4	0
December	5	5	0	5	5	0	5	5	0
<b>Total</b>	52	52	0	52	52	0	52	52	0

## Input into the Distribution System Bacteriological Data

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well # 4  
**Year:** 2025  
**Serviced Population:** 2864  
**Laboratories Which Performed Analyses:** Caduceon Labs

### Treated Water

Month	Total Coliform			Fecal Coliform/Escherichia Coli			HPC or MF		
	No. of Samples	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"
January	4	4	0	4	4	0	4	4	0
February	4	4	0	4	4	0	4	4	0
March	4	4	0	4	4	0	4	4	0
April	5	5	0	5	5	0	5	5	0
May	4	4	0	4	4	0	4	4	0
June	5	5	0	5	5	0	5	5	0
July	4	4	0	4	4	0	4	4	0
August	3	3	0	3	3	0	3	3	0
September	5	5	0	5	5	0	5	5	0
October	4	4	0	4	4	0	4	4	0
November	4	4	0	4	4	0	4	4	0
December	5	5	0	5	5	0	5	5	0
<b>Total</b>	<b>51</b>	<b>51</b>	<b>0</b>	<b>51</b>	<b>51</b>	<b>0</b>	<b>51</b>	<b>51</b>	<b>0</b>

## Input into the Distribution System Bacteriological Data

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well # 5  
**Year:** 2025  
**Serviced Population:** 2864  
**Laboratories Which Performed Analyses:** Caduceon Labs

### Treated Water

Month	Total Coliform			Fecal Coliform/Escherichia Coli			HPC or MF		
	No. of Samples	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"	No. of Samples Collected	No. of Samples "Safe"	No. of Samples "Unsafe"
January	4	4	0	4	4	0	4	4	0
February	4	4	0	4	4	0	4	4	0
March	4	4	0	4	4	0	4	4	0
April	5	5	0	5	5	0	5	5	0
May	4	4	0	4	4	0	4	4	0
June	5	5	0	5	5	0	5	5	0
July	4	4	0	4	4	0	4	4	0
August	4	4	0	4	4	0	4	4	0
September	5	5	0	5	5	0	5	5	0
October	4	4	0	4	4	0	4	4	0
November	4	4	0	4	4	0	4	4	0
December	5	5	0	5	5	0	5	5	0
<b>Total</b>	52	52	0	52	52	0	52	52	0

**Annual Summary - Raw Water (A Separate Sheet Should Be Completed For Each Raw Water Input To The Treatment Works) Bacteriological Data**

**Water Works Name:**

Dundalk Water Works

**Well No. (If applicable)**

Well # 3

**Year:**

2025

**Serviced Population:**

2864

**Laboratories Which Performed Analyses:**

Caduceon Labs

**Raw Water**

Month	Total Coliform			Fecal Coliform/Escherichia Coli		
	No. of Samples	No. of Samples 0 Organisms/100 ml	No. of Samples > 0 Organisms/100ml	No. of Samples Collected	No. of Samples 0 Org./100 ml	No. of Samples > 0 Organisms/100ml
January	4	4	0	4	4	0
February	4	4	0	4	4	0
March	4	4	0	4	4	0
April	5	5	0	5	5	0
May	4	4	0	4	4	0
June	5	5	0	5	5	0
July	4	3	1	4	4	0
August	4	4	0	4	4	0
September	5	5	0	5	5	0
October	4	4	0	4	4	0
November	4	4	0	4	4	0
December	5	5	0	5	5	0
<b>Total</b>	<b>52</b>	<b>51</b>	<b>1</b>	<b>52</b>	<b>52</b>	<b>0</b>

**Annual Summary - Raw Water (A Separate Sheet Should Be Completed For Each Raw Water Input To The Treatment Works) Bacteriological Data**

**Water Works Name:**

Dundalk Water Works

**Well No. (If applicable)**

Well # 4

**Year:**

2025

**Serviced Population:**

2864

**Laboratories Which Performed Analyses:**

Caduceon Labs

**Raw Water**

Month	Total Coliform			Fecal Coliform/Escherichia Coli		
	No. of Samples	No. of Samples 0 Organisms/100 ml	No. of Samples > 0 Organisms/100ml	No. of Samples Collected	No. of Samples 0 Org./100 ml	No. of Samples > 0 Organisms/100ml
January	4	4	0	4	4	0
February	4	4	0	4	4	0
March	4	4	0	4	4	0
April	5	5	0	5	5	0
May	4	4	0	4	4	0
June	5	5	0	5	5	0
July	4	4	0	4	4	0
August	4	4	0	4	4	0
September	5	5	0	5	5	0
October	0	0	0	0	0	0
November	0	0	0	0	0	0
December	0	0	0	0	0	0
<b>Total</b>	<b>39</b>	<b>39</b>	<b>0</b>	<b>39</b>	<b>39</b>	<b>0</b>

**Annual Summary - Raw Water (A Separate Sheet Should Be Completed For Each Raw Water Input To The Treatment Works) Bacteriological Data**

**Water Works Name:**

Dundalk Water Works

**Well No. (If applicable)**

Well # 5

**Year:**

2025

**Serviced Population:**

2864

**Laboratories Which Performed Analyses:**

Caduceon Labs

**Raw Water**

Month	Total Coliform			Fecal Coliform/Escherichia Coli		
	No. of Samples	No. of Samples 0 Organisms/100 ml	No. of Samples > 0 Organisms/100ml	No. of Samples Collected	No. of Samples 0 Org./100 ml	No. of Samples > 0 Organisms/100ml
January	4	4	0	4	4	0
February	4	4	0	4	4	0
March	4	4	0	4	4	0
April	5	5	0	5	5	0
May	4	4	0	4	4	0
June	5	5	0	5	5	0
July	4	4	0	4	4	0
August	4	4	0	4	4	0
September	5	5	0	5	5	0
October	4	4	0	4	4	0
November	4	4	0	4	4	0
December	5	5	0	5	5	0
<b>Total</b>	<b>52</b>	<b>52</b>	<b>0</b>	<b>52</b>	<b>52</b>	<b>0</b>

### Input into the Distribution System Bacteriological Data

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well # 3  
**Year:** 2025  
**Serviced Population:** 2864  
**Design Capacity:** 1181 m<sup>3</sup>/Day  
**Laboratories Which Performed Analyses:** Caduceon Labs

#### Treated Water

Month	Treated Water Flow			Influent Wastewater Monthly Total m <sup>3</sup>	Treated Water Turbidity			Treated Disinfectant		Dist. System Disinfectant	
	Average m <sup>3</sup>	Maximum Day m <sup>3</sup>	Monthly Total m <sup>3</sup>		No. of Samples Collected	No. of Samples > 1 NTU	Average Turbidity NTU	No. of Treated Samples Collected	Average Free Residual (mg/L)	No. of Dist. Samples	No. of Samples without Required Chlorine Residual
January	330	428	10238	45366	31	0	0.33	31	0.99	31	0
February	359	417	10051	30187	28	0	0.35	28	1.24	28	0
March	370	665	11457	98201	31	0	0.34	31	1.01	31	0
April	381	698	11438	72770	30	0	0.33	30	1.14	30	0
May	372	461	11533	39432	31	0	0.33	31	1.17	31	0
June	366	387	10974	31800	30	0	0.29	30	1.05	30	0
July	368	405	11416	29421	31	0	0.31	31	1.05	31	0
August	378	808	11727	24614	31	0	0.32	31	1.02	31	0
September	387	466	11618	21711	30	0	0.35	30	1.15	30	0
October	403	689	12498	22045	31	0	0.36	31	1.05	31	0
November	433	1083	12986	30683	30	0	0.26	30	1.20	30	0
December	405	531	12567	40591	31	0	0.30	31	1.22	31	0
<b>Total</b>			138503	486821	365	0		365		365	0
<b>Average</b>	379.333						0.32		1.11		
<b>Maximum</b>		1083.000									

Disinfectant Compound Used:  
(eg. Chlorine Gas, NaOCl, Etc.)

NaOCl

Form of Residual Displayed on Above Table:  
(I. E. Free, Combined, or Total)

Free

Distribution System Target Residual (mg./L):

> 0.2 Free

Recap for Month  
 Recap for Month

### Input into the Distribution System Bacteriological Data

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well # 4  
**Year:** 2025  
**Serviced Population:** 2864  
**Design Capacity:** 1636 m<sup>3</sup>/Day  
**Laboratories Which Performed Analyses:** Caduceon Labs

#### Treated Water

Month	Treated Water Flow			Influent Wastewater Monthly Total m3	Treated Water Turbidity			Treated Disinfectant		Dist. System Disinfectant	
	Average m3	Maximum Day m3	Monthly Total m3		No. of Samples Collected	No. of Samples > 1 NTU	Average Turbidity NTU	No. of Treated Samples Collected	Average Free Residual (mg/L)	No. of Dist. Samples Collected	No. of Samples without Required Chlorine Residual
January	359	436	11138	45366	31	0	0.08	31	1.00	31	0
February	356	617	9971	30187	28	0	0.08	28	1.04	28	0
March	369	653	11432	98201	31	0	0.08	31	1.06	31	0
April	359	439	10780	72770	30	0	0.07	30	1.11	30	0
May	361	417	11185	39432	31	0	0.06	31	1.07	31	0
June	358	429	10750	31800	30	0	0.04	30	1.07	30	0
July	364	460	11282	29421	31	0	0.07	31	0.99	31	0
August	81	363	2508	24614	19	4	0.63	19	0.88	31	0
September	168	440	5030	21711	30	0	0.14	30	0.99	30	0
October	6	14	176	22045	31	0	0.10	31	1.10	31	0
November	6	15	164	30683	30	0	0.12	30	0.71	30	0
December	6	14	177	40591	31	0	0.17	31	0.79	31	0
<b>Total</b>			84593	486821	353	4		353		365	0
<b>Average</b>	232.750						0.14		0.98		
<b>Maximum</b>		653.000									

Disinfectant Compound Used:  
(eg. Chlorine Gas, NaOCl, Etc.)

NaOCl

Form of Residual Displayed on Above Table:  
(I. E. Free, Combined, or Total)

Free

Distribution System Target Residual (mg./L.):

> 0.2 Free

	Water Consumption Report
	Recap for Month

### Input into the Distribution System Bacteriological Data

Water Works Name:	Dundalk Water Works
Well No. (If applicable)	Well # 5
Year:	2025
Serviced Population:	2864
Design Capacity:	1961 m <sup>3</sup> /Day
Laboratories Which Performed Analyses:	Caduceon Labs

#### Treated Water

Month	Treated Water Flow			Influent Wastewater Monthly Total m <sup>3</sup>	Treated Water Turbidity			Treated Disinfectant		Dist. System Disinfectant	
	Average m <sup>3</sup>	Maximum Day m <sup>3</sup>	Monthly Total m <sup>3</sup>		No. of Samples Collected	No. of Samples > 1 NTU	Average Turbidity NTU	No. of Treated Samples Collected	Average Free Residual (mg/L)	No. of Dist. Samples Collected	No. of Samples without Required Chlorine Residual
January	315	889	9755	45366	31	0	0.09	31	0.98	31	0
February	310	726	8682	30187	28	0	0.09	28	0.95	28	0
March	303	686	9405	98201	31	0	0.10	31	0.93	31	0
April	315	695	9456	72770	30	0	0.11	30	1.07	30	0
May	309	609	9570	39432	31	0	0.07	31	1.05	31	0
June	376	638	11276	31800	30	0	0.04	30	1.10	30	0
July	332	498	10300	29421	31	0	0.06	31	1.07	31	0
August	662	1076	20510	24614	31	0	0.09	31	1.06	31	0
September	591	1641	18321	21711	30	0	0.09	30	1.00	30	0
October	532	1249	15955	22045	31	0	0.10	31	1.10	31	0
November	542	947	16272	30683	30	0	0.05	30	1.10	30	0
December	650	907	20161	40591	31	0	0.09	31	1.08	31	0
<b>Total</b>			159663	486821	365	0		365		365	0
<b>Average</b>	436.417						0.08		1.04		
<b>Maximum</b>		1641.000									

Disinfectant Compound Used:  
(eg. Chlorine Gas, NaOCl, Etc.)

NaOCl

Form of Residual Displayed on Above Table:  
(I. E. Free, Combined, or Total)

Free

Distribution System Target Residual (mg./L):

> 0.2 Free

Water Consumption Report
Recap for Month

**Annual Report - Flouride, Nitrite, Nitrate, and Colour**

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name:	Dundalk Water Works
Well No. (If applicable)	Well # 3
Year:	2025
Serviced Population:	2864
Design Capacity:	1181 m <sup>3</sup> /Day
Laboratories Which Performed Analyses:	Caduceon Labs

Month	Treated Water Fluoride			Treated Water Nitrite			Treated Water Nitrate			Colour	
	No. of Samples Collected	Average Residual (mg/L)	Maximum Residual (mg/L)	No. of Samples Collected	Average Nitrite (mg/L)	Maximum Nitrite (mg/L)	No. of Samples Collected	Average Nitrate (mg/L)	Maximum Nitrate (mg/L)	Average Raw (TCU)	Average Treated (TCU)
January				1	0.08	0.08	1	0.69	0.69		
February											
March											
April				1	0.05	0.05	1	0.72	0.72		
May											
June											
July	2	0.55	0.6	1	0.1	0.1	1	0.60	0.60		
August											
September											
October				1	0.05	0.05	1	0.05	0.05		
November											
December											
<b>Total</b>	<b>2</b>			<b>4</b>			<b>4</b>				
<b>Average</b>		0.275			0.070			0.515			
<b>Maximum</b>			0.600			0.100			0.720		
<b>ODWO</b>			1.5		0.1	1		1	10		

Where Nitrate and Nitrite are present, the total of the two should not exceed 10mg/L.

Flouride levels above 1.5mg/L should be reported to the Medical Officer of Health.

**Annual Report - Flouride, Nitrite, Nitrate, and Colour**

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name:	Dundalk Water Works
Well No. (If applicable)	Well # 4
Year:	2025
Serviced Population:	2864
Design Capacity:	1636 m <sup>3</sup> /Day
Laboratories Which Performed Analyses:	Caduceon Labs

Month	Treated Water Fluoride			Treated Water Nitrite			Treated Water Nitrate			Colour	
	No. of Samples Collected	Average Residual (mg/L)	Maximum Residual (mg/L)	No. of Samples Collected	Average Nitrite (mg/L)	Maximum Nitrite (mg/L)	No. of Samples Collected	Average Nitrate (mg/L)	Maximum Nitrate (mg/L)	Average Raw (TCU)	Average Treated (TCU)
January				1	0.05	0.05	1	1.82	1.82		
February											
March											
April				1	0.05	0.05	1	1.88	1.88		
May											
June											
July	2	1.05	1.1	1	0.06	0.06	1	1.81	1.81		
August											
September											
October				1	0.05	0.05	1	2.06	2.06		
November											
December											
<b>Total</b>	<b>2</b>			<b>4</b>			<b>4</b>				
<b>Average</b>		0.525			0.053			1.893			
<b>Maximum</b>			1.1			0.06			2.06		
<b>ODWO</b>			1.5		0.1	1		1	10		

Where Nitrate and Nitrite are present, the total of the two should not exceed 10mg/L.

Flouride levels above 1.5mg/L should be reported to the Medical Officer of Health.

**Annual Report - Flouride, Nitrite, Nitrate, and Colour**

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

Water Works Name:	Dundalk Water Works
Well No. (If applicable)	Well # 5
Year:	2025
Serviced Population:	2864
Design Capacity:	1961 m <sup>3</sup> /Day
Laboratories Which Performed Analyses:	Caduceon Labs

Month	Treated Water Fluoride			Treated Water Nitrite			Treated Water Nitrate			Colour	
	No. of Samples Collected	Average Residual (mg/L)	Maximum Residual (mg/L)	No. of Samples Collected	Average Nitrite (mg/L)	Maximum Nitrite (mg/L)	No. of Samples Collected	Average Nitrate (mg/L)	Maximum Nitrate (mg/L)	Average Raw (TCU)	Average Treated (TCU)
January	2	1.85	1.9	1	0.05	0.05	1	0.050	0.050		
February											
March											
April				1	0.05	0.05	1	0.05	0.05		
May											
June											
July	2	1.85	1.9	1	0.05	0.05	1	0.05	0.05		
August											
September											
October				1	0.05	0.05	1	0.05	0.05		
November											
December											
<b>Total</b>	<b>4</b>			<b>4</b>			<b>4</b>				
<b>Average</b>		0.925			0.050			0.050			
<b>Maximum</b>			1.9			0.05			0.05		
<b>ODWO</b>			1.5		0.1	1		1	10		

Where Nitrate and Nitrite are present, the total of the two should not exceed 10mg/L.

Flouride levels above 1.5mg/L should be reported to the Medical Officer of Health.

### Annual Data Summary - Treated Water Volatile Organic & Inorganic Data

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well #3  
**Year:** 2025  
**Serviced Population:** 2864  
**Design Capacity:** 1181 m<sub>3</sub>/Day  
**Laboratories Which Performed Analyses:** Caduceon Labs

**Treated Water (except for Lead, THM's and HAA's which should be sampled for in the distribution system)**

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested	ODWO MAC/IMAC/AO (ug/L)
	Date	Results (ug/L)	Date (DD/MMM/YY)	Results (ug/L)	Date (DD/MMM/YY)	Results (ug/L)	Date (DD/MMM/YY)	Results (ug/L)			
<b>TABLE B VOLATILE ORGANICS</b>											
Benzene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.32	9-Mar-15	0.32	3 years	4-Mar-24	1
Carbon Tetrachloride	4-Mar-24	<0.2	1-Mar-21	<0.2	5-Mar-18	0.16	9-Mar-15	0.16	3 years	4-Mar-24	2
1, 2 - Dichlorobenzene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.41	9-Mar-15	0.41	3 years	4-Mar-24	200
1, 4 - Dichlorobenzene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.36	9-Mar-15	0.36	3 years	4-Mar-24	5
1, 2 - Dichloroethane	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.35	9-Mar-15	0.35	3 years	4-Mar-24	5
1, 1 - Dichloroethylene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.33	9-Mar-15	0.33	3 years	4-Mar-24	14
Dichloromethane	4-Mar-24	<5	1-Mar-21	<5	5-Mar-18	0.35	9-Mar-15	0.35	3 years	4-Mar-24	50
Ethybenzene	1-Nov-00	<0.0024							Aesthetic Objective	1-Nov-00	140
Monochlorobenzene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.3	9-Mar-15	0.3	3 years	4-Mar-24	80
Tetrachloroethylene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.35	9-Mar-15	0.35	3 years	4-Mar-24	10
Toluene/Trichloroethylene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.44	9-Mar-15	0.44	3 years	4-Mar-24	60
Vinyl Chloride	4-Mar-24	<0.2	1-Mar-21	<0.2	5-Mar-18	0.17	9-Mar-15	0.17	3 years	4-Mar-24	1
Xylene	1-Nov-00	0.005							Aesthetic Objective	1-Nov-00	90
<b>TABLE C - INORGANICS</b>											
Arsenic	4-Mar-24	0.001	1-Mar-21	0.00120	5-Mar-18	2.6	9-Mar-15	2.2	3 years	4-Mar-24	10
Barium	4-Mar-24	0.107	1-Mar-21	0.10500	5-Mar-18	126	9-Mar-15	116	3 years	4-Mar-24	1000
Boron	4-Mar-24	0.047	1-Mar-21	0.05400	5-Mar-18	55	9-Mar-15	57.6	3 years	4-Mar-24	5000
Cadmium	4-Mar-24	<0.000015	1-Mar-21	<0.000015	5-Mar-18	0.003	9-Mar-15	0.005	3 years	4-Mar-24	5
Chromium	4-Mar-24	<0.0010	1-Mar-21	<0.002	5-Mar-18	0.21	9-Mar-15	0.03	3 years	4-Mar-24	50
Copper	1-Nov-00	<0.005							Aesthetic Objective	1-Nov-00	1000
Iron	13-Jan-13	15	20-Dec-12	10	10-Sep-12	8	18-Jul-12	10	Aesthetic Objective	13-Jan-13	300
Lead	20-Sep-17	1.33	14-Mar-17	0.43	15-Sep-16	0.33	17-Mar-16	3.68		20-Sep-17	10
Manganese	13-Jan-13	5.6	20-Dec-12	6	12-Apr-08	7.0			Aesthetic Objective	13-Jan-13	20
Mercury	4-Mar-24	<0.00002	1-Mar-21	<0.00002	5-Mar-18	0.01	9-Mar-15	0.01	3 years	4-Mar-24	1
Selenium	4-Mar-24	<0.001	1-Mar-21	<0.001	5-Mar-18	0.07	9-Mar-15	1	3 years	4-Mar-24	50
Uranium	4-Mar-24	0.0021	1-Mar-21	0.001930	5-Mar-18	1.53	9-Mar-15	2.1	3 years	4-Mar-24	20
Zinc	1-Jan-01	<0.01							Aesthetic Objective	23-Jan-01	5000

### Annual Data Summary - Treated Water Volatile Organic & Inorganic Data

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well # 4  
**Year:** 2025  
**Serviced Population:** 2864  
**Design Capacity:** 1636 m<sub>3</sub>/Day  
**Laboratories Which Performed Analyses:** Caduceon Labs

**Treated Water (except for lead, THM's and HAA's which should be sampled for in the distribution system)**

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested (year)	ODWO MAC/IMAC/AO (ug/L)
	Date	Results (ug/L)	Date (DD/MMM/YY)	Results (ug/L)	Date (DD/MMM/YY)	Results (ug/L)	Date (DD/MMM/YY)	Results (ug/L)			
<b>TABLE B VOLATILE ORGANICS</b>											
Benzene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.32	9-Mar-15	0.32	3 years	4-Mar-24	1
Carbon Tetrachloride	4-Mar-24	<0.2	1-Mar-21	<0.2	5-Mar-18	0.16	9-Mar-15	0.16	3 years	4-Mar-24	2
1, 2 - Dichlorobenzene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.41	9-Mar-15	0.41	3 years	4-Mar-24	200
1, 4 - Dichlorobenzene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.36	9-Mar-15	0.36	3 years	4-Mar-24	5
1, 2 - Dichloroethane	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.35	9-Mar-15	0.35	3 years	4-Mar-24	5
1, 1 - Dichloroethylene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.33	9-Mar-15	0.33	3 years	4-Mar-24	14
Dichloromethane	4-Mar-24	<5	1-Mar-21	<5	5-Mar-18	0.35	9-Mar-15	0.35	3 years	4-Mar-24	50
Ethybenzene	22-Dec-04	0.47	1-Jun-02	<0.0005					Aesthetic Objective	22-Dec-04	140
Monochlorobenzene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.3	9-Mar-15	0.3	3 years	4-Mar-24	80
Tetrachloroethylene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.35	9-Mar-15	0.35	3 years	4-Mar-24	10
Toluene/Trichloroethylene	4-Mar-24	<0.5	1-Mar-21	<0.5	5-Mar-18	0.44	9-Mar-15	0.44	3 years	4-Mar-24	60
Vinyl Chloride	4-Mar-24	<0.2	1-Mar-21	<0.2	5-Mar-18	0.17	9-Mar-15	0.17	3 years	4-Mar-24	1
Xylene	1-Jun-02	<0.0015							Aesthetic Objective	1-Jun-02	90
<b>TABLE C - INORGANICS</b>											
Arsenic	4-Mar-24	0.0004	1-Mar-21	0.00030	5-Mar-18	0.5	9-Mar-15	0.6	3 years	4-Mar-24	10
Barium	4-Mar-24	0.099	1-Mar-21	0.09600	5-Mar-18	113	9-Mar-15	103	3 years	4-Mar-24	1000
Boron	4-Mar-24	0.039	1-Mar-21	0.04000	5-Mar-18	40	9-Mar-15	44.7	3 years	4-Mar-24	5000
Cadmium	4-Mar-24	<0.000015	1-Mar-21	<0.000015	5-Mar-18	0.006	9-Mar-15	0.007	3 years	4-Mar-24	5
Chromium	4-Mar-24	<0.0010	1-Mar-21	<0.002	5-Mar-18	0.14	9-Mar-15	0.03	3 years	4-Mar-24	50
Copper	22-Dec-04	1.2	1-Jun-02	<0.001					Aesthetic Objective	22-Dec-04	1000
Iron	22-Dec-04	<10							Aesthetic Objective	22-Dec-04	300
Lead	20-Sep-17	0.77	14-Mar-17	0.57	14-Sep-16	1.34	17-Mar-16	4.72		20-Sep-17	10
Manganese	22-Dec-04	22							Aesthetic Objective	22-Dec-04	20
Mercury	4-Mar-24	<0.00002	1-Mar-21	<0.00002	5-Mar-18	0.01	9-Mar-15	0.01	3 years	4-Mar-24	1
Selenium	4-Mar-24	<0.001	1-Mar-21	<0.001	5-Mar-18	0.26	9-Mar-15	1	3 years	4-Mar-24	50
Uranium	4-Mar-24	0.00174	1-Mar-21	0.001750	5-Mar-18	1.52	9-Mar-15	1.39	3 years	4-Mar-24	20
Zinc	22-Dec-04	3	1-Jun-02	0.006					Aesthetic Objective	22-Dec-04	5000

### Annual Data Summary - Treated Water Volatile Organic & Inorganic Data

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well # 5  
**Year:** 2025  
**Serviced Population:** 2864  
**Design Capacity:** 1961 m<sub>3</sub>/Day  
**Laboratories Which Performed Analyses:** Caduceon Labs

**Treated Water (except for lead, THM's and HAA's which should be sampled for in the distribution system)**

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested (year)	ODWO MAC/IMAC/AO (ug/L)
	Date	Results (ug/L)	Date (DD/MMM/YY)	Results (ug/L)	Date (DD/MMM/YY)	Results (ug/L)	Date (DD/MMM/YY)	Results (ug/L)			
<b>TABLE B VOLATILE ORGANICS</b>											
Benzene	4-Mar-24	<0.5	1-Mar-21	<0.5	22-Jan-20	<0.5	27-Jan-17	<0.5	3 years	4-Mar-24	1
Carbon Tetrachloride	4-Mar-24	<0.2	1-Mar-21	<0.2	22-Jan-20	<0.2	27-Jan-17	<0.5	3 years	4-Mar-24	2
1, 2 - Dichlorobenzene	4-Mar-24	<0.5	1-Mar-21	<0.5	22-Jan-20	<0.5	27-Jan-17	<0.5	3 years	4-Mar-24	200
1, 4 - Dichlorobenzene	4-Mar-24	<0.5	1-Mar-21	<0.5	22-Jan-20	<0.5	27-Jan-17	<0.5	3 years	4-Mar-24	5
1, 2 - Dichloroethane	4-Mar-24	<0.5	1-Mar-21	<0.5	22-Jan-20	<0.5	27-Jan-17	<0.5	3 years	4-Mar-24	5
1, 1 - Dichloroethylene	4-Mar-24	<0.5	1-Mar-21	<0.5	22-Jan-20	<0.5	27-Jan-17	<0.5	3 years	4-Mar-24	14
Dichloromethane	4-Mar-24	<5	1-Mar-21	<5	22-Jan-20	<5	27-Jan-17	<2.0	3 years	4-Mar-24	50
Ethybenzene	27-Jan-17	<0.5	17-Oct-16	<0.5					Aesthetic Objective	27-Jan-17	140
Monochlorobenzene	4-Mar-24	<0.5	1-Mar-21	<0.5	22-Jan-20	<0.5	27-Jan-17	<0.5	3 years	4-Mar-24	80
Tetrachloroethylene	4-Mar-24	<0.5	1-Mar-21	<0.5	22-Jan-20	<0.5	27-Jan-17	<0.5	3 years	4-Mar-24	10
Toluene/Trichloroethylene	4-Mar-24	<0.5	1-Mar-21	<0.5	22-Jan-20	<0.5	27-Jan-17	<0.5	3 years	4-Mar-24	60
Vinyl Chloride	4-Mar-24	<0.2	1-Mar-21	<0.2	22-Jan-20	<0.2	27-Jan-17	<0.5	3 years	4-Mar-24	1
Xylene	27-Jan-17	<1.1	17-Oct-16	<1.1					Aesthetic Objective	27-Jan-17	90
<b>TABLE C - INORGANICS</b>											
Arsenic	4-Mar-24	0.0007	1-Mar-21	0.00080	21-Jan-20	0.0004	27-Jan-17	<0.0010	3 years	4-Mar-24	10
Barium	4-Mar-24	0.104	1-Mar-21	0.10500	21-Jan-20	0.098	27-Jan-17	0.095	3 years	4-Mar-24	1000
Boron	4-Mar-24	0.043	1-Mar-21	0.04800	21-Jan-20	0.048	27-Jan-17	<0.050	3 years	4-Mar-24	5000
Cadmium	4-Mar-24	<0.000015	1-Mar-21	<0.000015	21-Jan-20	<0.000015	27-Jan-17	<0.00010	3 years	4-Mar-24	5
Chromium	4-Mar-24	<0.0010	1-Mar-21	<0.002	21-Jan-20	<0.002	27-Jan-17	<0.0010	3 years	4-Mar-24	50
Copper	27-Jan-17	<0.0010	17-Oct-16	<0.0010					Aesthetic Objective	27-Jan-17	1000
Iron	27-Jan-17	0.051	17-Oct-16	0.062					Aesthetic Objective	27-Jan-17	300
Lead	27-Jan-17	<0.00050	17-Oct-16	<0.00062						27-Jan-17	10
Manganese	27-Jan-17	0.001	17-Oct-16	0.0023					Aesthetic Objective	27-Jan-17	20
Mercury	4-Mar-24	<0.00002	1-Mar-21	<0.00002	23-Jan-20	<0.00002	27-Jan-17	<0.10	3 years	4-Mar-24	1
Selenium	4-Mar-24	<0.001	1-Mar-21	<0.001	21-Jan-20	<0.001	27-Jan-17	<0.0050	3 years	4-Mar-24	50
Uranium	4-Mar-24	0.00035	1-Mar-21	0.000350	21-Jan-20	0.00016	27-Jan-17	<0.0050	3 years	4-Mar-24	20
Zinc	27-Jan-17	<0.0030	17-Oct-16	0.0102					Aesthetic Objective	27-Jan-17	5000

**Annual Data Summary - Parameters Not Listed in the Minimum Sampling Program**

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well # 3  
**Year:** 2025  
**Serviced Population:** 2864  
**Design Capacity:** 1181 m<sup>3</sup>/Day  
**Laboratories Which Performed Analyses:** Caduceon Labs

**Treated Water (Except for Lead Which Should Be Sampled For in the Distribution System)**

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested	ODWO MAC/IMAC/AO (mg/L)
	Date	Results (mg/L)	Date (DD/MMM/YY)	Results (mg/L)	Date (DD/MMM/YY)	Results (mg/L)	Date (DD/MMM/YY)	Results (mg/L)			
OTHER PARAMETERS (List as Required)		<=====	<=====	<=====	<=====	<=====	<=====	<=====	<=====	<=====	<=====
Hardness	13-Jan-13	281	20-Dec-12	288	12-Apr-08	268			Operational Objective	13-Jan-13	80 - 100
Sodium	15-Jul-25	24.9	4-Mar-24	30.2	4-Jul-23	28.1	7-Mar-23	28.9	Annually	4-Mar-24	20
Fluoride	15-Jul-25	0.5	8-Jul-25	0.6	4-Apr-23	0.5	8-Mar-22	0.4	5 years	15-Jul-25	1.5
Hydrogen Sulphide									Aesthetic Objective		0.05
Alkalinity as Ca CO <sub>3</sub>	7-Mar-23	245	7-Mar-23	259	13-Jan-13	251	20-Dec-12	264	Operational Objective	7-Mar-23	30 - 500
Chloride	9-Jul-24	41.5	9-Jan-24	42.7	10-Jan-23	42.9	19-Jul-22	39.1	Operational Objective	9-Jan-24	250
Sulphate	13-Jan-13	17	20-Dec-12	17					Aesthetic Objective	13-Jan-13	500
Organic Nitrogen 6	13-Jan-13	0.14	20-Dec-12	0.05					Operational Objective	13-Jan-13	0.15
Dissolved Organic C	12-Apr-08	0.8							Aesthetic Objective	12-Apr-08	5
Nitrilotriacetic Acid	23-Jan-01	<0.3								23-Jan-01	0.4
Total Dissolved Solids	13-Jan-13	409	12-Apr-08	334					Aesthetic Objective	13-Jan-13	500
Total Cyanide	10-Jan-01	0.2								10-Jan-01	0.2
Benzo (a) Pyrenene	4-Mar-24	<0.006	1-Mar-21	<0.006	5-Mar-18	0.004	11-Mar-15	0.004	3 years	4-Mar-24	0.01 ug/l
N-Nitrosodimethylamine	23-Jan-01	<0.000007								23-Jan-01	0.000009
Ammonia	8-Oct-24	0.41	9-Jan-24	0.36	10-Oct-23	0.33	14-Oct-22	0.47		8-Oct-24	
Nitrates	7-Oct-25	<0.05	8-Jul-25	0.6	1-Apr-25	0.72	7-Jan-25	0.69	Quarterly	7-Oct-25	10
Nitrites	7-Oct-25	<0.05	8-Jul-25	0.1	1-Apr-25	<0.05	7-Jan-25	0.08	Quarterly	7-Oct-25	1
Pesticides & PCB's	4-Mar-24	<0.05	1-Mar-21	<0.05	9-Mar-15	0.04	5-Mar-12	0.04		4-Mar-24	3
pH	31-Dec-15	7.58	13-Jan-13	7.98	20-Dec-12	8.01			Operational Objective	31-Dec-15	6.5 - 8.5
Radionuclides-Gross Alpha	25-Mar-25	0.15	4-Mar-24	<0.10	7-Mar-23	<0.10	8-Mar-22	0.19	Annually	25-Mar-25	0.5 bq/l
Radionuclides-Gross Beta	25-Mar-25	0.16	4-Mar-24	0.13	7-Mar-23	<0.10	8-Mar-22	0.12	Annually	25-Mar-25	1.0 bq/l
Radionuclides-Tritium	25-Mar-25	<15	4-Mar-24	<15	7-Mar-23	<15	8-Mar-22	<15	Annually	25-Mar-25	7000 bq/l
True Colour (TCU)									Aesthetic Objective		5 TCU

**Annual Data Summary - Parameters Not Listed in the Minimum Sampling Program**

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well # 4  
**Year:** 2025  
**Serviced Population:** 2864  
**Design Capacity:** 1636 m<sup>3</sup>/Day  
**Laboratories Which Performed Analyses:** Caduceon Labs

**Treated Water (Except for Lead Which Should Be Sampled For in the Distribution System)**

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested	ODWO MAC/IMAC/AO (mg/L)
	Date	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)			
OTHER PARAMETERS (List as Required)		<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<	<<<<	<<<<<<<<
Hardness	22-Dec-04	236							Operational Objective	22-Dec-04	80 - 100
Sodium	15-Jul-25	21.8	4-Mar-24	30.3	4-Jul-23	24.9	7-Mar-23	26.6	Annually	15-Jul-25	20
Fluoride	15-Jul-25	1	8-Jul-25	1.1	4-Apr-23	0.7	8-Mar-22	0.5	5 years	15-Jul-25	1.5
Hydrogen Sulphide									Aesthetic Objective		0.05
Alkalinity as Ca CO <sub>3</sub>	7-Mar-23	245	7-Mar-23	259	4-Dec-22	247			Operational Objective	7-Mar-23	30 - 500
Chloride	9-Jul-24	41	9-Jan-24	45.6	10-Jan-23	41.1	19-Jul-22	38.6	Operational Objective	9-Jan-24	250
Sulphate	22-Dec-04	9.8							Aesthetic Objective	22-Dec-04	500
Organic Nitrogen 6	22-Dec-04	0.05							Operational Objective	22-Dec-04	0.15
Dissolved Organic C	22-Dec-04	0.2							Aesthetic Objective	22-Dec-04	5
Nitri洛triacetic Acid	22-Dec-04	0.03								22-Dec-04	0.4
Total Dissolved Solids	22-Dec-04	303							Aesthetic Objective	22-Dec-04	500
Total Cyanide	22-Dec-04	0.2								22-Dec-04	0.2
Benzo (a) Pyrenene	4-Mar-24	<0.006	1-Mar-21	<0.006	5-Mar-18	0.004	11-Mar-15	0.004	3 years	4-Mar-24	0.01 ug/l
N-Nitrosodimethylamine	22-Dec-04	0.0012								22-Dec-04	0.000009
Ammonia	22-Dec-04	0.06								22-Dec-04	
Nitrates	7-Oct-25	2.06	8-Jul-25	1.81	1-Apr-25	1.88	7-Jan-25	1.82	Quarterly	7-Oct-25	10
Nitrites	7-Oct-25	<0.05	8-Jul-25	0.06	1-Apr-25	<0.05	7-Jan-25	<0.05	Quarterly	7-Oct-25	1
Pesticides & PCB's	4-Mar-24	<0.05	1-Mar-21	<0.05	9-Mar-15	0.04	5-Mar-12	0.004		4-Mar-24	3
pH	31-Dec-15	7.5							Operational Objective	31-Dec-15	6.5 - 8.5
Radionuclides-Gross Alpha	25-Mar-25	<0.1	4-Mar-24	<0.13	7-Mar-23	<0.10	8-Mar-22	<0.10	Annually	25-Mar-25	0.5 bq/l
Radionuclides-Gross Beta	25-Mar-25	<0.1	4-Mar-24	<0.10	7-Mar-23	<0.10	8-Mar-22	0.13	Annually	25-Mar-25	1.0 bq/l
Radionuclides-Tritium	25-Mar-25	<15	4-Mar-24	<15	7-Mar-23	<15	8-Mar-22	<15	Annually	25-Mar-25	7000 bq/l
True Colour (TCU)	22-Dec-04	3							Aesthetic Objective	22-Dec-04	5 TCU

### Annual Data Summary - Parameters Not Listed in the Minimum Sampling Program

(A Separate Sheet Should Be Completed for Each Input into the Distribution System)

**Water Works Name:** Dundalk Water Works  
**Well No. (If applicable)** Well # 5  
**Year:** 2025  
**Serviced Population:** 2864  
**Design Capacity:** 1961 m<sub>3</sub>/Day  
**Laboratories Which Performed Analyses:** Caduceon Labs

#### **Treated Water (Except for Lead Which Should Be Sampled For in the Distribution System)**

Parameters	Analysis No. 1		Analysis No. 2		Analysis No. 3		Analysis No. 4		Sampling Frequency	Last Date Parameter Tested	ODWO MAC/IMAC/AO (mg/L)
	Date	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)	Date (MM/DD/YY)	Results (mg/L)			
OTHER PARAMETERS (List as Required)		<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<<<<<	<<<<	<<<<	<<<<<<<
Hardness	27-Jan-17	231000	17-Oct-16	265000					Operational Objective	27-Jan-17	80000-100000
Sodium	15-Jul-25	12.4	4-Mar-24	13.3	4-Jul-23	12.7	7-Mar-23	13.2	Annually	4-Mar-24	20
Fluoride	15-Jul-25	1.8	8-Jul-25	1.9	10-Jan-25	1.8	7-Jan-25	1.9	5 years	15-Jul-25	1.5
Hydrogen Sulphide	27-Jan-17	<0.21	17-Oct-16	0.22					Aesthetic Objective	27-Jan-17	0.05
Alkalinity as Ca CO <sub>3</sub>	7-Mar-23	245	7-Mar-23	259	27-Jan-17	243	17-Oct-16	248	Operational Objective	7-Mar-23	30 - 500
Chloride	9-Jul-24	14.7	9-Jan-24	14.4	10-Jan-23	15.4	19-Jul-22	15.7	Operational Objective	9-Jan-24	250
Sulphate	27-Jan-17	<0.020	17-Oct-16	0.021					Aesthetic Objective	27-Jan-17	500
Organic Nitrogen 6	27-Jan-17	<0.15							Operational Objective	27-Jan-17	0.15
Dissolved Organic C	27-Jan-17	1.4	17-Oct-16	1.7					Aesthetic Objective	27-Jan-17	5
Nitrilotriacetic Acid	27-Jan-17	<0.20	17-Oct-16	<0.20					27-Jan-17	0.4	
Total Dissolved Solids	27-Jan-17	279	17-Oct-16	281					27-Jan-17	500	
Total Cyanamide	27-Jan-17	<0.0020	17-Oct-16	<0.0020					27-Jan-17	0.2	
Benzo (a) Pyrenene	4-Mar-24	<0.006	1-Mar-21	<0.006	27-Jan-17	<0.010	17-Oct-16	<0.010	3 years	4-Mar-24	0.01 ug/l
N-Nitrosodimethylamine	27-Jan-17	1.8	17-Oct-16	0.71					27-Jan-17	9	
Ammonia	27-Jan-17	0.056	17-Oct-16	0.051					27-Jan-17		
Nitrates	7-Oct-25	<0.05	8-Jul-25	<0.05	1-Apr-25	<0.05	7-Jan-25	<0.05	Quarterly	7-Oct-25	10
Nitrites	7-Oct-25	<0.05	8-Jul-25	<0.05	1-Apr-25	<0.05	7-Jan-25	<0.05	Quarterly	7-Oct-25	1
Pesticides & PCB's	4-Mar-24	<0.05	1-Mar-21	<0.05					4-Mar-24	3	
pH	27-Jan-17	7.4	17-Oct-16	8					Operational Objective	27-Jan-17	6.5 - 8.5
Radionuclides-Gross Alpha	25-Mar-25	<0.1	4-Mar-24	<0.16	7-Mar-23	<0.10	8-Mar-22	0.13	Annually	25-Mar-25	0.5 bq/l
Radionuclides-Gross Beta	25-Mar-25	<0.1	4-Mar-24	<0.10	7-Mar-23	<0.10	8-Mar-22	<0.10	Annually	25-Mar-25	1.0 bq/l
Radionuclides-Tritium	25-Mar-25	<15	4-Mar-24	<15	7-Mar-23	<15	8-Mar-22	<15	Annually	25-Mar-25	7000 bq/l
True Colour (TCU)	27-Jan-17	<2.0	17-Oct-16	<2.0					Aesthetic Objective	27-Jan-17	5 TCU

## Annual Data Summary - Distribution System Volatile Organic Compounds Data

### Total Haloacetic (HAA) Annual Average Results

Quarter	Quarter Dates	Sample 1	Sample 2	Sample 3	Sample 4	Quarterly Average (ug/L)	MAC (maximum allowable concentration)
1-2025	07-Jan-25	<5.3	<5.3			<5.3	
2-2025	01-Apr-25	<5.3	<5.3			<5.3	
3-2025	08-Jul-25	10.2	11.2			10.7	
4-2025	07-Oct-25	8.2	<5.0			6.6	
<b>(RAA) Running Annual Average</b>						6.975	80 ug/L

### Total Trihalomethane (THM) Annual Average Results

Quarter	Quarter Dates	Sample 1	Sample 2	Sample 3	Sample 4	Quarterly Average (ug/L)	MAC (Maximum allowable concentration)
1-2025	07-Jan-25	11	15			13	
2-2025	01-Apr-25	13	17			15	
3-2025	08-Jul-25	14	21			17.5	
4-2025	07-Oct-25	26	12			19	
<b>(RAA) Running Annual Average</b>						16.125	100 ug/L