



Township of Southgate

Dundalk Wastewater Treatment Plant

2025 Annual Report

9.1.3 PW2026-008 - Dundalk Wastewater 2025 Annual Report

No. 2026-061

Moved By Councillor Ferguson
Seconded By Councillor Singh Soares

Be it resolved that Staff Report PW2026-008 be received for information; and
That; Council approve the Dundalk Wastewater Treatment Plant 2025 Annual Report.

Carried

Cory Henry
Public Works Manager – Water Operations

Dundalk Wastewater Treatment Plant

2025 Annual Report

Table of Contents

| | |
|---|----|
| Wastewater Treatment Plant Annual Overview..... | 1 |
| 2025 General Wastewater Information..... | 5 |
| Loading Report..... | 6 |
| Performance Report..... | 7 |
| Final Effluent Discharge Report..... | 8 |
| Raw Sewage Parameters and Lab Results..... | 9 |
| Final Effluent Parameters and Lab Results..... | 10 |

Overview:

The Dundalk Wastewater Treatment Plant (WWTP) provided treatment in 2025 with an annual average influent daily flow of 1,331 m³/day, a 6.19% decrease over the 2024 average influent daily flow of 1,419 m³/day.

Project Description:

The Dundalk WWTP is a four-cell waste stabilization pond facility flowing into an aeration cell pond with a chemical feed system and a flocculation tank with tertiary treatment consisting of sand filters.

Plant Facts:

Facilities: Waste Stabilization Ponds with Tertiary Treatment

Design Capacity: 1832 m³/day

Receiver Water: Foley Drain/Grand River

Environmental Compliance

Approval: 5657-9D9LYE

Effluent Requirements:

| Effluent Parameter | Ideal | Maximum | Maximum |
|------------------------------|---|---|---|
| | Concentration Objective | Monthly Average Concentration (MAC) | Monthly Average Loading |
| COB ₅ | 5.0 mg/L | 10.0 mg/L | 18.32 kg/day |
| Total Suspended Solids (TSS) | 5.0 mg/L | 10.0 mg/L | 18.32 kg/day |
| Total Phosphorous | 0.30 mg/L + 5 degrees Celsius stream temperature 0.60 mg/L - 5 degrees Celsius stream temperature | 0.40 mg/L + 5 degrees Celsius stream temperature 0.80 mg/L - 5 degrees Celsius stream temperature | 0.73 kg/L + 5 degrees Celsius stream temperature 1.47 kg/L - 5 degrees Celsius stream temperature |
| Dissolved Oxygen | 5.0 mg/L | 4.0 mg/L | |
| Unionized Ammonia | 0.05 mg/L | 0.1 mg/L | |
| pH | 6.5 to 8.5 at all times | 6.0 to 9.5 at all times | |

Sampling Requirements:

Sampling Criteria for this system is in accordance with Ministry Policy for the Environmental Compliance Approval (ECA) No. 5657-9D9LYE

Final Effluent:

A grab sample is taken twice a month and tested for CBOD, Suspended Solids, Total Phosphorus, Total Ammonia Nitrogen, Ecoli and pH.

On site testing is performed twice a week on final effluent for Total Ammonia to determine Unionized Ammonia through in-house testing of pH and temperature.

Raw Sewage:

A grab sample is taken monthly and tested for BOD, Suspended Solids, Total Kjeldahl Nitrogen and Total Phosphorus.

Effluent Flows:

The total effluent flow treated in 2025 was 493,826 m³, which results in a 0.86% decrease of total effluent over 2024. The annual average daily flow while discharging was 1,554 m³/day.

Raw Sewage Quality:

- Annual average raw sewage BOD concentration to the lagoon system was 165.9 mg/l.
- Annual average raw sewage suspended solids (TSS) concentration to the lagoon system was 281.0 mg/l.
- Annual average raw total phosphorus was 5.76 mg/l concentration to the lagoon system.
- Annual average Total Kjeldahl Nitrogen (TKN) concentration was 60.2 mg/l.

Plant Performance and Effluent Quality:

- Annual average effluent CBOD concentration was 4.88 mg/l.
- Annual average effluent total suspended solids (TSS) concentration was 5.4 mg/l day with a removal efficiency of 97.49% with an annual monthly average loading of 9.9 kg/day.
- Annual average effluent total phosphorus concentration was 0.13 mg/l day with a removal efficiency of 96.73% with an annual monthly average loading of 0.20 kg/day.
- Annual average effluent concentration for Ammonia-nitrogen was 9.29 mg/l.
- Annual average Unionized Ammonia was 0.054285 mg/l.
- Annual average pH was 7.97.
- Annual monthly average Ecoli was 1006 with the low being 2 and the high being 8396.
- The summary for 2025 of the data for the systems plant operation performance is enclosed in this report.

Maintenance and Calibration Activities:

Regular monthly preventative maintenance and calibration of test equipment and flow meters are performed by municipal staff and outside certified suppliers.

Third party annual calibrations were performed on October 16, 2025.

There was 0 by-pass events to report

The Township and Triton Engineering have developed a mitigation plan including enhanced monitoring and reporting to the MECP.

There were 6 operator shutdowns in 2025.

Please reference below table for shutdowns and limit exceedances for 2025.

2025 Wastewater effluent parameters compliance exceedances and shutdowns

| | Monthly Average Effluent Concentration | | | | | Monthly Average Effluent Loading (kg/d) | | | Lagoon Shutdown Duration | Comments |
|-----|--|-----------|----------------------------------|---|--------------|---|--------------|--|--------------------------|--|
| | COB5 | TSS | TP | Unionized Ammonia | pH | COB5 | TSS | TP | | |
| | Limit | Limit | Limit | Limit | Limit | Limit | Limit | Limit | | |
| | 10.0 mg/day | 10.0 mg/L | 0.4 mg/L ->5 C 0.8 mg/L -<5 C | 0.05 mg/L = daily testing 0.13 mg/L = proactive shutdown 0.15 mg/L = shutdown | <6.0 or >9.5 | 18.32 kg/day | 18.32 kg/day | 0.73 kg/day >5 C 1.47 kg/day -<5 C | | |
| JAN | | | | | | | | | | |
| FEB | 12 | 9.5 | | | | 24 | 19 | | 16.2 | 16.2 days >10 mg/L TSS 16.2 days TSS loading 16.2 days >10 mg/L CBOD 16.2 days CBOD loading |
| MAR | 27.7 | 19 | | | | 11.6 | 16.3 | | 25.5 | 5.5 days >10 mg/L TSS 5.5 days TSS loading 5.5 days >10 mg/L CBOD 5.5 days CBOD loading |
| APR | 4 | 4 | | 0.131 | | | | | 4.8 | 1.4 days >10 mg/L TSS 3.4 days >0.15 UIA |
| MAY | | | | 0.0725 | | | | | 1 | 1 day > 0.15mg/L UIA |
| JUN | | | | | | | | | | |
| JUL | | | | | | | | | | |
| AUG | | | | | | | | | | |
| SEP | | | | | | | | | | |
| OCT | | | | | | | | | | |
| NOV | | | | | | | | | | |
| DEC | | | | | | | | | | |

Note: If daily testing for unionized ammonia occurs on a Friday we shut down for the weekend.

- Shutdown due to exceedance.
- Shutdown as a proactive measure due to approaching an exceedance.

Note: There was an oversight of February CBOD exceedance. We should not have started up on February 25.

This was realized on March 6th and immediately shut down upon realization.

Note: MECP inspector interpretation of C of A, unionized ammonia limit, allows discharge of effluent with <0.15mg/L.

There were loading exceedances in February and March for effluent suspended solids and CBOD. We discharged for 11.8 days in February and 5.5 days in March.

Discussion:

The Dundalk Wastewater Treatment upgrades are awaiting Ministry approval of the ECA amendment for the Dundalk Sewage Works.

Upon issuance of the ECA amendment, Triton Engineering will release the tender documents, followed by award of the contract by Southgate Council. Construction is anticipated for 2026 for the first phase of the upgrades.

Installation of a new influent sewage pumping station to manage increased flow effectively. Additionally, enhancements such as incorporation of additional aeration and a floating cover in the final cell of the lagoons, will aid in algae removal, thus improving overall treatment efficiency.

A major component of this project is the construction of a 22m x 5.5m concrete tank utilizing advanced Moving Bed Biofilm Reactor (MBBR) technology, which will optimize ammonia reduction.

Upgrading the tertiary media filter to a state-of-the-art disk filter system will ensure effective removal of Total Suspended Solids.

Finally, implementing a new Ultraviolet (UV) disinfection system will play a critical role in reducing E.coli levels, thereby enhancing the quality of treated wastewater.

This expansion is expected to increase the treatment capacity of the facility by over 65% from 1832m³/day to 3025m³/day.

The Township of Southgate received from the MECP a Consolidated Linear Infrastructure – Environmental Compliance Approval (CLI-ECA) for the Municipal Sewage Collection System, ECA Number 110-W601, issued March 2, 2023.

Township of Southgate - Village of Dundalk

2025 General Wastewater Information

Plant # : 0-101006-67

ECA # : 5657-9D9LYE

Population: 2,864 (Village of Dundalk)

Flows

| | Design | 2025 | 2024 | 2023 | 2022 | 2021 | 2020 | 2019 | 2018 | 2017 | 2016 | 2015 | 2014 | 2013 | 2012 | 2011 | 2010 | 2009 | 2008 | |
|--|---------|----------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Capacity: | 208,500 | | | | | | | | | | | | | | | | | | | |
| Influent Average Daily: | - | m ₃ | 1,331 | 1,419 | 1,237 | 990 | 1,220 | 1,161 | 1,114 | 1,105 | 1,168 | 986 | 728 | 996 | 2,221 | 1,183 | 1,164 | 1,020 | 1,217 | 1,482 |
| Annual Influent Flow: | 668,600 | m ₃ | 486,821 | 518,945 | 450,793 | 360,770 | 446,719 | 425,922 | 405,664 | 401,279 | 424,727 | 360,118 | 265,878 | 364,601 | 808,274 | 434,232 | 425,447 | 372,117 | 444,350 | 542,455 |
| Influent Maximum Daily: | - | m ₃ | 7,827 | 5,736 | 4,017 | 3,247 | 6,740 | 4,510 | 3,989 | 9,022 | 6,362 | 4,820 | 2,458 | 2,873 | 3,991 | 3,926 | 4,453 | 4,390 | 4,258 | 4,577 |
| Effluent Average Daily (days operating): | 1,832 | m ₃ | 1,550 | 1,785 | 1,497 | 1,196 | 2,096 | 1,087 | 1,315 | 1,355 | 1,230 | 1,090 | 1,181 | 1,636 | 1,394 | 1,136 | 1,332 | 1,245 | 1,466 | 1,631 |
| Annual Effluent Flow: | - | m ₃ | 493,826 | 498,096 | 384,666 | 312,215 | 470,150 | 396,688 | 407,659 | 404,853 | 420,598 | 334,685 | 389,776 | 494,185 | 505,962 | 369,351 | 435,622 | 434,339 | 535,214 | 597,173 |
| % Discharge vs. Total Capacity: | - | | 73.9% | 74.5% | 57.5% | 46.7% | 70.3% | 59.3% | 61.0% | 60.6% | 62.9% | 50.1% | 58.3% | 73.9% | 75.7% | 55.2% | 65.2% | 65.0% | 80.0% | 89.3% |
| Influent Decrease 2025 over 2024: | - | | -6.19% | 15.12% | 24.95% | -19.24% | 4.88% | 4.99% | 1.09% | -5.52% | 17.94% | 35.44% | -27.08% | -54.89% | 86.14% | 2.06% | 14.33% | -16.26% | -18.09% | 35.54% |
| Effluent Decrease 2025 over 2024: | - | | -0.86% | 29.49% | 23.21% | -33.59% | 18.52% | -2.69% | 0.69% | -3.74% | 25.67% | -14.13% | -21.13% | -2.33% | 36.99% | -15.21% | 0.30% | -18.85% | -10.38% | 62.28% |

Township of Southgate
Loading Report - Dundalk Wastewater Plant

Municipality: Township of Southgate Year: 2025
 Plant: Dundalk Wastewater Treatment Lagoons & Collection System
 Plant #: 0-101006-67
 Works #: 110001471
 System Description : Facultative Lagoons & Sand Filters

| Month | Loading Influent | | | Effluent Loading | | |
|-----------|------------------|--------------|-------------------|----------------------------|--------------------------|-------------------------------|
| | BOD kg/day | SS kg/day | T Phos. kg/day | Effluent CBOD kg/day | Effluent SS kg/day | Effluent T Phos. kg/day |
| January | 165.3 | 288.2 | 6.0 | 14.5 | 15.6 | 0.44 |
| February | 158.5 | 294.3 | 4.7 | 24.0 | 19.0 | 0.62 |
| March | 396.0 | 446.7 | 9.8 | 27.7 | 38.9 | 1.17 |
| April | 286.3 | 346.9 | 5.8 | 8.1 | 8.1 | 0.28 |
| May | 232.8 | 324.4 | 7.0 | 6.5 | 7.6 | 0.04 |
| June | 164.3 | 265.0 | 6.9 | 6.3 | 6.3 | 0.08 |
| July | 170.8 | 291.8 | 6.9 | 5.5 | 7.3 | 0.08 |
| August | 168.3 | 284.3 | 7.5 | 3.7 | 3.7 | 0.06 |
| September | 152.8 | 309.9 | 4.6 | 2.8 | 2.8 | 0.08 |
| October | 152.2 | 261.6 | 7.3 | 1.9 | 2.2 | 0.04 |
| November | 188.2 | 350.9 | 5.2 | 2.2 | 2.9 | 0.02 |
| December | 195.0 | 403.2 | 5.9 | 4.4 | 4.4 | 0.06 |
| Total | 2430.5 | 3867.1 | 77.8 | 107.7 | 118.9 | 2.97 |
| Average | 202.5 | 322.3 | 6.5 | 9.0 | 9.9 | 0.25 |
| Maximum | 396.0 | 446.7 | 9.8 | 27.7 | 38.9 | 1.17 |

PS = Plant Shutdown

= loading exceedance

Township of Southgate
Performance Report - Dundalk Wastewater Plant

Municipality: Township of Southgate
 Plant: Dundalk Wastewater Treatment Lagoons & Collection System
 Plant #: 0-101006-67
 Works #: 110001471
 System Description: Facultative Lagoons & Sand Filters

Year: 2025
 Receiver: Foley Drain - Grand River
 Design Average Day Flow (m³): 1832

| Month | Flows | | | Discharge Duration Days | Bio-Chemical Oxygen Demand | | | Suspended Solids | | | Phosphorus | | | E Coli average Effluent Count | Temperature | | Nitrogen Series | | | Loading | | |
|-----------|------------------------------|-----------------------------|-----------------------------|----------------------------|----------------------------|-------------------------------|--------------------|------------------------|-----------------------------|--------------------|-----------------------------|----------------------------------|--------------------|--|------------------------|-------------|--|------------------------------|----------------------------|--------------------------|-------------------------------|-----|
| | Total Flow m ³ | Avg. Flow m ³ | Max. Flow m ³ | | Avg. Raw BOD mg/l | Avg. Effluent CBOD mg/l | Percent Removal | Avg. Raw SS mg/l | Avg. Effluent SS mg/l | Percent Removal | Avg. Raw T. Phos mg/l | Avg. Effluent T. Phos mg/l | Percent Removal | | < 5 C. or > 5 C. | TKN mg/l | Avg. Effluent NH ₃ + NH ₄ mg/l | Unionized Ammonia mg/l | Effluent CBOD kg/day | Effluent SS kg/day | Effluent T Phos. kg/day | |
| January | 45366 | 1463.00 | 2655.00 | 64390 | 31 | 113.0 | 7.0 | 93.81% | 197.0 | 7.5 | 96.19% | 4.10 | 0.21 | 94.88% | 8396 | 0.2 | 48.8 | 18.65 | 0.066188 | 14.5 | 15.6 | 0.4 |
| February | 30187 | 1078.00 | 1438.00 | 23967 | 12 | 147.0 | 12.0 | 91.84% | 273.0 | 9.5 | 96.52% | 4.40 | 0.31 | 92.95% | 1068 | 0.5 | 44.2 | 24.65 | 0.129465 | 24.0 | 19.0 | 0.6 |
| March | 98201 | 3168.0 | 6594.0 | 13124 | 5.5 | 125.0 | 11.6 | 90.7% | 141.0 | 16.3 | 88.4% | 3.1 | 0.49 | 84.2% | 2509 | 1.7 | 32.4 | 29.16 | 0.105100 | 27.7 | 38.9 | 1.2 |
| April | 72770 | 2426.00 | 7827.00 | 52800 | 26.2 | 118.0 | 4.0 | 96.61% | 143.0 | 4.0 | 97.20% | 2.40 | 0.14 | 94.17% | 53 | 7.2 | 25.4 | 17.30 | 0.131900 | 8.1 | 8.1 | 0.3 |
| May | 39432 | 1272.00 | 1685.00 | 65316 | 30 | 183.0 | 3.0 | 98.36% | 255.0 | 3.5 | 98.63% | 5.50 | 0.02 | 99.64% | 3 | 14.3 | 59.7 | 4.64 | 0.072532 | 6.5 | 7.6 | 0.0 |
| June | 31800 | 1060.00 | 1292.00 | 63215 | 30 | 155.0 | 3.0 | 98.06% | 250.0 | 3.0 | 98.80% | 6.50 | 0.04 | 99.38% | 2 | 20.5 | 65.1 | 0.05 | 0.003788 | 6.3 | 6.3 | 0.1 |
| July | 29421 | 949.00 | 1361.00 | 56946 | 31 | 180.0 | 3.0 | 98.33% | 307.5 | 4.0 | 98.70% | 7.30 | 0.05 | 99.38% | 3 | 24.6 | 68.0 | 0.05 | 0.002133 | 5.5 | 7.3 | 0.1 |
| August | 24614 | 794.00 | 1079.00 | 38328 | 31 | 212.0 | 3.0 | 98.58% | 358.0 | 3.0 | 99.16% | 9.50 | 0.05 | 99.47% | 3 | 22.0 | 106.4 | 1.45 | 0.002179 | 3.7 | 3.7 | 0.1 |
| September | 21711 | 724.00 | 864.00 | 28410 | 30 | 211.0 | 3.0 | 98.58% | 428.0 | 3.0 | 99.30% | 6.40 | 0.08 | 98.75% | 2 | 17.9 | 98.0 | 0.07 | 0.007960 | 2.8 | 2.8 | 0.1 |
| October | 22045 | 711.00 | 775.00 | 19885 | 31 | 214.0 | 3.0 | 98.60% | 368.0 | 3.5 | 99.05% | 10.30 | 0.06 | 99.42% | 5 | 12.5 | 60.0 | 1.02 | 0.010577 | 1.9 | 2.2 | 0.0 |
| November | 30683 | 1023.00 | 1521.00 | 21703 | 30 | 184.0 | 3.0 | 98.37% | 343.0 | 4.0 | 98.83% | 5.10 | 0.03 | 99.41% | 2 | 3.2 | 68.1 | 3.4 | 0.032402 | 2.2 | 2.9 | 0.0 |
| December | 40591 | 1309.00 | 2422.00 | 45742 | 31 | 149.0 | 3.0 | 97.99% | 308.0 | 3.0 | 99.03% | 4.50 | 0.04 | 99.11% | 27 | 0.7 | 46.6 | 11.02 | 0.087193 | 4.4 | 4.4 | 0.1 |
| Total | 486821 | | | 493826 | 318.7 | | | | | | | | | | | | | | | | | |
| Average | 40568 | 1331 | | 41152 | | 165.9 | 4.88 | 96.65% | 281.0 | 5.4 | 97.49% | 5.76 | 0.13 | 96.73% | 1006 | 10.4 | 60.2 | 9.29 | 0.054285 | 9.0 | 9.9 | 0.2 |
| Maximum | 98201 | 3168 | 7827 | 65316 | | 214.0 | 12.0 | | 428.0 | 16.3 | | 10.30 | 0.49 | | 8396 | 24.6 | 106.4 | 29.16 | 0.131900 | 27.7 | 38.9 | 1.2 |

PS = Plant Shutdown

Township of Southgate
Annual Report - Dundalk Wastewater Plant

Plant: Dundalk Wastewater Treatment Lagoons & Collection System
 Works: 110001471
 Year: 2025
 Location Type: Final Effluent Discharge Report

| Month | Discharge Duration Days | Total Effluent m ³ | Total Coagulant Used (kg) | Average Coagulant Dosage (mg/l) | Average CBOD mg/l | Average SS mg/l | Average T. Phos. mg/l | Average NH ₃ + NH ₄ as N (mg/l) | E Coli average Count | Average pH Reports | Average Temp. C | Average D.O. mg/l |
|-----------|-------------------------|-------------------------------|---------------------------|---------------------------------|-------------------|-----------------|-----------------------|---|----------------------|--------------------|-----------------|-------------------|
| January | 31 | 64390 | 1.55 | 15.6 | 7.0 | 7.5 | 0.21 | 18.65 | 8396 | 7.86 | 0.20 | 10.19 |
| February | 12 | 23967 | 0.60 | 16.3 | 12.0 | 9.5 | 0.31 | 24.65 | 1068 | 8.15 | 0.50 | 8.69 |
| March | 5.5 | 13124 | 0.28 | 13.6 | 11.6 | 16.3 | 0.49 | 29.16 | 2509 | 7.76 | 1.70 | 10.79 |
| April | 26.2 | 52800 | 1.31 | 16.1 | 4.0 | 4.0 | 0.14 | 17.30 | 53 | 8.03 | 7.20 | 10.42 |
| May | 30 | 65316 | 1.50 | 14.9 | 3.0 | 3.5 | 0.02 | 4.64 | 3 | 7.55 | 14.30 | 7.66 |
| June | 30 | 63215 | 1.50 | 15.4 | 3.0 | 3.0 | 0.04 | 0.05 | 2 | 7.71 | 20.50 | 6.81 |
| July | 31 | 56946 | 1.55 | 17.7 | 3.0 | 4.0 | 0.05 | 0.05 | 3 | 8.10 | 24.60 | 7.50 |
| August | 31 | 38328 | 1.55 | 26.3 | 3.0 | 3.0 | 0.05 | 1.45 | 3 | 7.88 | 22.00 | 22.00 |
| September | 30 | 28410 | 1.50 | 34.3 | 3.0 | 3.0 | 0.08 | 0.07 | 2 | 8.44 | 17.90 | 9.92 |
| October | 31 | 19885 | 1.55 | 50.7 | 3.0 | 3.5 | 0.06 | 1.02 | 5 | 8.14 | 12.50 | 10.83 |
| November | 30 | 21703 | 1.50 | 44.9 | 3.0 | 4.0 | 0.03 | 3.38 | 2 | 7.88 | 3.20 | 11.32 |
| December | 31 | 45742 | 1.55 | 22.0 | 3.0 | 3.0 | 0.04 | 11.02 | 27 | 8.08 | 0.70 | 13.73 |
| Total | 318.7 | 493826 | 15.94 | | | | | | | | | |
| Average | | 41152 | 1.33 | 23.99 | 4.88 | 5.36 | 0.13 | 9.29 | 1006 | 7.97 | 10.44 | 10.82 |
| Maximum | | 65316 | | | 12 | 16.3 | 0.49 | 29.16 | 8396 | 8.44 | 24.60 | 22.00 |

PS = Plant Shutdown

Township of Southgate - Village of Dundalk
Annual Report - Dundalk Wastewater Plant

Plant: Dundalk Wastewater Treatment Lagoons & Collection System
Works: 110001471
Classification: Class 1 Wastewater Collection & Class 1 Wastewater Treatment
Receiver: Foley Drain to Grand River

Year: 2025
Population Served: 2864

| Raw Sewage Parameters | | January | February | March | April | May | June | July | August | September | October | November | December | Summary |
|-------------------------|---------|---------|----------|-------|-------|------|------|------|--------|-----------|---------|----------|----------|---------|
| | Average | 113 | 147 | 119 | 118 | 183 | 155 | 180 | 212 | 211 | 214 | 184 | 149 | 165 |
| BOD | Minimum | 63 | 140 | 54 | 106 | 169 | 149 | 147 | 193 | 165 | 182 | 138 | 131 | 136 |
| mg/l | Maximum | 163 | 153 | 184 | 130 | 197 | 160 | 213 | 230 | 256 | 245 | 229 | 167 | 194 |
| Suspended Solids | Average | 197 | 273 | 143 | 143 | 255 | 250 | 308 | 358 | 428 | 368 | 343 | 308 | 281 |
| Solids | Minimum | 190 | 260 | 66 | 126 | 210 | 154 | 275 | 285 | 285 | 320 | 280 | 285 | 228 |
| mg/l | Maximum | 204 | 285 | 220 | 160 | 300 | 345 | 340 | 430 | 570 | 415 | 405 | 330 | 334 |
| | Average | 48.5 | 44.2 | 38.0 | 25.4 | 59.7 | 65.1 | 68.0 | 106.4 | 98.0 | 60.5 | 68.0 | 46.5 | 60.7 |
| TKN | Minimum | 36.0 | 39.6 | 14.2 | 17.4 | 58.2 | 63.1 | 64.6 | 72.8 | 78.9 | 38.0 | 53.0 | 32.0 | 47.3 |
| mg/l | Maximum | 61.0 | 48.8 | 61.8 | 33.4 | 61.2 | 67.1 | 71.3 | 140.0 | 117.0 | 83.0 | 83.0 | 61.0 | 74.1 |
| Total Phosphorus | Average | 4.06 | 4.37 | 3.37 | 2.38 | 5.56 | 6.47 | 7.25 | 9.46 | 6.40 | 10.29 | 5.11 | 4.52 | 5.77 |
| Phosphorus | Minimum | 2.23 | 3.74 | 1.45 | 1.48 | 5.41 | 5.42 | 7.11 | 6.82 | 5.85 | 5.97 | 1.50 | 2.90 | 4.16 |
| mg/l | Maximum | 5.89 | 5.00 | 5.29 | 3.27 | 5.71 | 7.52 | 7.39 | 12.10 | 6.95 | 14.60 | 8.71 | 6.13 | 7.38 |

PS = Plant Shutdown

Township of Southgate - Village of Dundalk
Annual Report - Dundalk Wastewater Plant

Plant: Dundalk Wastewater Treatment Lagoons & Collection System
Works: 110001471
Classification: Class 1 Wastewater Collection & Class 1 Wastewater Treatment
Receiver: Foley Drain to Grand River

Year: 2025
Population Served: 2803

| Final Effluent Parameters | January | February | March | April | May | June | July | August | September | October | November | December | Summary |
|---|---------|----------|----------|----------|----------|----------|----------|----------|-----------|----------|----------|----------|----------|
| | Average | 7.0 | 12.0 | 12.0 | 4.0 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 | 4.9 |
| CBOD | Minimum | 6.0 | 8.0 | 7 | 3 | 3.0 | 3.0 | 3 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 |
| mg/l | Maximum | 8.0 | 16.0 | 17 | 5 | 3.0 | 3.0 | 3 | 3.0 | 3.0 | 3.0 | 3.0 | 17.0 |
| Suspended Solids | Average | 7.5 | 9.5 | 15.5 | 4.0 | 3.5 | 3.0 | 4.0 | 3.0 | 3.0 | 3.5 | 4.0 | 5.3 |
| Solids | Minimum | 7.0 | 7.0 | 12 | 4 | 3.0 | 3.0 | 3 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 |
| mg/l | Maximum | 8.0 | 12.0 | 19 | 4 | 4.0 | 3.0 | 5 | 3.0 | 3.0 | 4.0 | 5.0 | 19.0 |
| | Average | 18.7 | 24.7 | 29.2 | 17.3 | 4.6 | 0.1 | 0.1 | 0.1 | 1.0 | 3.4 | 11.0 | 9.17 |
| NH3 + NH4 | Minimum | 17.30 | 22.40 | 28.6 | 12.3 | 7.19 | 0.05 | 0.05 | 0.05 | 0.10 | 3.30 | 6.40 | 0.05 |
| mg/l | Maximum | 20.00 | 26.90 | 29.8 | 22.3 | 2.08 | 0.05 | 0.05 | 0.07 | 1.90 | 3.50 | 15.60 | 29.80 |
| | Average | 22.60 | 30.40 | 35.80 | 19.30 | 5.90 | 0.90 | 1.15 | 1.45 | 1.45 | 2.75 | 4.90 | 14.80 |
| TKN | Minimum | 20.90 | 30.40 | 31 | 13.7 | 2.60 | 0.90 | 1 | 1.40 | 1.40 | 1.80 | 4.90 | 8.70 |
| mg/l | Maximum | 24.30 | 30.40 | 40.6 | 24.9 | 9.20 | 0.90 | 1.3 | 1.50 | 1.50 | 3.70 | 4.90 | 20.90 |
| Total | Average | 0.21 | 0.31 | 0.50 | 0.14 | 0.02 | 0.04 | 0.05 | 0.06 | 0.08 | 0.06 | 0.03 | 0.04 |
| Phosphorus | Minimum | 0.20 | 0.29 | 0.37 | 0.04 | 0.02 | 0.04 | 0.04 | 0.04 | 0.07 | 0.04 | 0.03 | 0.02 |
| mg/l | Maximum | 0.21 | 0.32 | 0.62 | 0.24 | 0.02 | 0.04 | 0.05 | 0.07 | 0.08 | 0.07 | 0.03 | 0.05 |
| | Average | 8396.00 | 3192.00 | 3418.00 | 53.00 | 3.00 | 2.00 | 3.00 | 3.00 | 2.00 | 8.00 | 2.00 | 50.00 |
| Ecoli | Minimum | 392 | 184 | 36 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 8 | 2 |
| | Maximum | 16400 | 6200 | 6800 | 104 | 4 | 2 | 4 | 4 | 2 | 14 | 2 | 92 |
| pH Lab Results (In-house testing not included) | Average | 7.86 | 7.90 | 7.75 | 8.03 | 7.56 | 7.71 | 8.10 | 7.88 | 8.44 | 8.14 | 7.88 | 8.08 |
| | Minimum | 7.81 | 7.88 | 7.65 | 8.02 | 7.21 | 7.46 | 8.09 | 7.81 | 8.37 | 8.04 | 7.82 | 7.99 |
| | Maximum | 7.90 | 7.92 | 7.85 | 8.04 | 7.90 | 7.96 | 8.11 | 7.94 | 8.51 | 8.23 | 7.93 | 8.16 |
| | Average | 10.60 | 9.25 | 10.00 | 10.35 | 7.65 | 6.55 | 6.85 | 9.20 | 10.00 | 10.55 | 11.70 | 13.10 |
| DO | Minimum | 8.70 | 6.80 | 6.4 | 8.3 | 6.20 | 4.70 | 5.3 | 8.40 | 9.30 | 8.20 | 9.40 | 11.70 |
| mg/l | Maximum | 12.50 | 11.70 | 13.6 | 12.4 | 9.10 | 8.40 | 8.4 | 10.00 | 10.70 | 12.90 | 14.00 | 14.50 |
| Unionized Ammonia | Average | 0.073001 | 0.080400 | 0.130250 | 0.149450 | 0.085150 | 0.004550 | 0.005450 | 0.002655 | 0.008750 | 0.011761 | 0.040964 | 0.084413 |
| mg/l | Minimum | 0.040143 | 0.027100 | 0.035100 | 0.024600 | 0.002900 | 0.000200 | 0.000300 | 0.000310 | 0.000900 | 0.000348 | 0.021247 | 0.034848 |
| | Maximum | 0.105858 | 0.133700 | 0.225400 | 0.274300 | 0.167400 | 0.008900 | 0.010600 | 0.005000 | 0.016600 | 0.023173 | 0.060680 | 0.133977 |
| | | | | | | | | | | | | | 0.274300 |

PS = Plant Shutdown